

Tenant Fire Safety Information

Brooklyn Drive

Publication date: March 2026

Version Number: V1

Contents

- Tenant Fire Safety Information 1**
 - Brooklyn Drive 1**
- 1 Introduction 3**
- 2 Fire Risk Assessment (FRA) 4**
- 3 Fire Risk Assessment Recommendations and Action Plan 5**
- 4 Mitigation Strategy 12**
- 5 Evacuation Plan 13**
- 6 Fire Safety Advice 14**
- 7 Further Information 16**
- 8 Who to contact 17**

1 Introduction

- 1.1 At Kirklees Council, we want our tenants to be as safe as they can be in their homes. This extends to many areas of our work with you, including fire safety. Your home in **Brooklyn Drive** is one of several buildings where we, as your landlord, are required to meet specific rules and regulations. This document gives you the information you need to understand how we are meeting our obligations, provides information in relation to fire safety specific to your building and how we propose to address works that are required to continue to keep you safe.
- 1.2 The key legislation that we are required to meet is listed below.
 - Regulatory Reform (Fire Safety) Order 2005 (FSO)
 - The Fire Safety Act 2021
 - The Fire Safety (England) Regulations 2022
 - The Building Safety Act 2022
- 1.3 More information about this legislation is available online and can be accessed by using the QR codes or web addresses provided at the end of this document. Links to this information are also available on the Kirklees Homes & Neighbourhoods website available at [Kirklees.gov.uk/council-housing](https://kirklees.gov.uk/council-housing).
- 1.4 As your landlord we are responsible for completing a periodic Fire Risk Assessment (FRA) and completing any actions that arise from that assessment. You can see these outlined in section 3. In addition to actions that we need to complete, our contractors may also make recommendations. These could include upgrades that are not required to meet the regulations but are good practice. We will also note these in section 3.
- 1.5 In this document you will find:
 - An explanation of a Fire Risk Assessment and what it means for you
 - A table that outlines actions and recommendations for your building
 - A plan for mitigating the risks that exist whilst actions remain outstanding
 - The building evacuation plan.
 - Safety advice
 - A list of people you can contact if you have any queries.

2 Fire Risk Assessment (FRA)

We have a legal duty under the Fire Safety Regulations (2022) to identify and remove any risks and hazards, or to reduce these as far as possible. A Fire Risk Assessment is carried out annually on your building by an independent qualified assessor to assess the fire safety of your building. The FRA looks internally and externally at:

- **Fire hazards** – things that could start a fire.
- **People at risk** – who might be affected if a fire happens.
- **Safety measures** – what is in place to prevent fires and keep people safe (like alarms, fire doors, and escape routes).
- **Actions needed** – any actions required to make the building safer.

A copy of the full fire risk assessment for **Brooklyn Drive** is available on request. Please contact HNFire@kirklees.gov.uk.

3 Fire Risk Assessment Recommendations and Action Plan

3.1 Where the FRA has identified actions that are needed to improve the fire safety of your building, we create an action plan to ensure that the actions are managed correctly. The actions are then risk assessed and a plan is created to ensure that the actions are completed. Where actions are not due to be completed immediately, we ensure that appropriate fire safety mitigations are in place to manage the risks and keep you safe.

Below is a table of the actions and recommendations that were identified in the last FRA for your building. This includes what actions we have taken to date and whether the action has been completed or is still required. This information is accurate as of 10/12/2025. You can find the latest position and updates on the Kirklees Homes and Neighbourhoods website.

3.2 Actions and Recommendations

Action	Action Taken to Date	Responsible Service	STATUS
It is Pennington Choices Limited (PCL) recommendation that advice is sought from a competent person to determine whether lightning protection is required or not for the building in accordance with BS EN 62305-2:2012.	Lightning protection is not required in a low-rise block. Low rise buildings fall below the height of a strike probability. It's our aspiration to install lightning protection on three storey and above buildings by March 2029.	Building Safety Team	Complete
Residents of this General Needs property should be encouraged to contact the building manager if they require assistance in developing a personal emergency evacuation plan (PEEP) or other fire safety advice. This could be achieved by adding a contact reference for assistance to the fire action	The contact details for the Building Safety Team are 01484 414886 or email HNFire@kirklees.gov.uk . We are developing processes relating to PCFRAs and PEEPs, which includes securing funding	Building Safety Team	In Progress

Action	Action Taken to Date	Responsible Service	STATUS
<p>notices for the premises, by providing additional separate notices containing the information or by making direct contact with residents via letter, flyer or website for example. Where a resident self-identifies with vulnerabilities that could impact their ability to escape in a fire, such assistance with PEEPs etc. as may be considered necessary should be provided.</p>	<p>and identifying dedicated resources internally.</p>		
<p>The surface-mounted wiring system secured with plastic clips and loosely secured as noted within the common escape route should be replaced with a cable support system which ensures that wiring is not liable to premature collapse in event of a fire.</p>	<p>BS 7671 is not retrospective and existing installations are not required to be upgraded in order to conform with the standard. Small sections of cable such as this are not considered to be an unacceptable life safety risk to either occupants nor firefighters. However we acknowledge this recommendation and this will be addressed in the block's next communal rewire.</p>	<p>Building Safety Team</p>	<p>Complete</p>

Action	Action Taken to Date	Responsible Service	STATUS
It should be confirmed/ensured that a policy is in place and communicated to residents which covers what can and cannot be stored and used on balconies. This should include policy/advice on combustible storage, smoking materials and barbecue.	Annual fire door, balcony and fire safety leaflets specific to the building were sent to tenants on the 11 March 2025 and are sent annually thereafter.	Building Safety Team	Complete
It should be confirmed that the locked doors next to the rear exit doors are 30 minute fire rated doors.	Doors are checked regularly and if found to be damaged or unsuitable a job will be raised for either a repair or temporary door replacement. Assets to upgrade all doors to FD30s on a programme of works.	Assets	Required
Based on the outcome of section P1, if the fire alarm is to remain in the building, provide a Zone Plan of the fire alarm system, fixed to the wall adjacent to the fire alarm panel.	This requires a zone plan depending on the decision taken regarding the communal alarm system	Property Services	Required
'No Smoking' signage should be provided in the common area.	Signage installed	Neighbourhoods	Complete

Action	Action Taken to Date	Responsible Service	STATUS
Management should ensure that the electrical intake/meter cupboard is inspected to confirm that combustible items are not being kept near ignition sources.	This is undertaken as part of the weekly inspection.	Building Safety Team	Complete
A sample check should be made of the boxed-in services ductwork to confirm that the construction is adequately fire resisting and that compartmentation behind has not been compromised at services penetrations etc.	A full compartmentation survey is to be undertaken for the block identifying any compartmentation breaches and rectify accordingly.	Assets	Required
It should be confirmed by reference to certification that the fire barrier system installed as compartmentation in the roof space provides the required period of fire resistance.	A full compartmentation survey is to be undertaken for the block identifying any compartmentation breaches and rectify accordingly.	Assets	Required
Management should check compartmentation within the two locked cupboards to confirm/ensure that they are enclosed with fire rated construction and adequately fire stopped.	A full compartmentation survey is to be undertaken for the block identifying any compartmentation breaches and rectify accordingly.	Assets	Required

Action	Action Taken to Date	Responsible Service	STATUS
Management should confirm and ensure that adequate arrangements are in place for silencing and resetting an alarm condition.	If the communal alarm activates Kirklees Corporate Fire Team attend, silence and reset alarm once confirmed by WYFRS.	Building Safety Team	Complete
The combustible items noted should be removed from the common area as soon as possible and a programme of regular checks put in place to ensure that the common area is kept clear.	The combustible material noted on the FRA has been removed.	Building Safety Team	Complete
It should be confirmed that the secure door entry system continues to operate in the event of a power failure or fails safe to open. If not, an emergency override facility will be required. The Euro key lock on the rear gate should be replaced with an easy opening device (e.g. thumb turn) to enable the gate to be opened from the inside without the use of a key. 'Turn to Open' signage indicating the turn direction of the lock should be provided.	Assigned to Property Services to arrange test and confirmation of electromagnetic doors into the premises are set to fail-safe and unlock in the event of power outage. If this is not the case an EDR should be fitted	Property Services	Required
Management should ensure/confirm that all flat entrance doors are 30 minute fire rated doors	Doors are checked regularly and if found to be damaged or unsuitable a	Assets	Required

Action	Action Taken to Date	Responsible Service	STATUS
including being fitted with three fire rated hinges, intumescent strips and seals and a self-closer.	job will be raised for either a repair or temporary door replacement. Assets to upgrade all doors to FD30s on a programme of works.		
The Grade A common area fire alarm system should be confirmed as having been designed and installed to support the Stay Put strategy. This requires there to be no common system smoke/heat detectors and sounders in flats and that the sound pressure level within flats from the common system does not exceed 45dB(A).	Decision taken in the FRA safety group 25/11/2025 to remove the detection in the communal areas of blocks with a stay put policy.	Property Services	In Progress
Management should ensure that an ongoing rolling programme of checks is in place to confirm that all flats in the building are fitted with a working smoke alarm to Grade D1 LD2 standard in accordance with BS58396:2019.	Detection will be upgraded a minimum of LD2 or better, identified on a risk-based evaluation, as part of a programme of works.	Building Safety Team	Required
A fire action notice advising of the 'Stay Put' evacuation policy should be provided in the common areas.	The FRA shows there are at least two fire action notices within the block.	Building Safety Team	Complete
Provide a fire exit signage above the rear exit			

Action	Action Taken to Date	Responsible Service	STATUS
---------------	-----------------------------	----------------------------	---------------

door. A "Fire Exit Keep Clear" signage should also be provided on the outside of the same exit door.

4 Mitigation Strategy

4.1 Flat Fire Alarm

Each flat has its own fire alarm system that meets the required standard. This includes smoke detectors in areas that people move through (such as hallways and landings) and in rooms presenting a high fire risk (such as living rooms and kitchens), together with heat detection in kitchens where appropriate. The fire alarm system provides early warning to the residents, ensuring they can respond quickly to a developing fire.

4.2 Emergency lighting

The building has an emergency lighting system designed to ensure safe evacuation during power failures or fire emergencies. These lights brighten escape routes, stairways, and exit signs, ensuring that residents can be guided safely to the exits. The system is checked monthly to make sure these emergency lights are operational and working.

4.3 Fire Safety Inspections

Responsible officer: Caretaker

Frequency: Weekly

Focus: General environmental safety both internal and external of the building, including communal areas.

Key areas checked:

- Vehicles around the perimeter.
- Fire panel operation and review of previous faults.
- Emergency lighting system (control panel and bulbs).
- Fire exit routes are clear and hazard-free.
- Trip hazards inside the property.
- Communal fire doors operation.
- Signage condition, including Fire Safety Notice.
- Walls, glazing, bin chutes, flat doors, and dry risers.
- Record any additional actions/comments.

5 Evacuation Plan

5.1 Evacuation Strategy

The evacuation strategy for your building is 'Stay Safe'. You may also hear this called a 'Stay Put' policy. This means:

- **If there is a fire in your flat** - you should leave the flat and the building.
- **If there is a fire somewhere else in the building** - you can stay in your flat and do not have to evacuate unless directed otherwise by the fire service or you feel safer to evacuate.

5.2 Evacuation Procedure for Occupants

If a fire breaks out in your flat:

- If you are in the room where the fire is, leave straight away, together with anyone else, then close the door
- Do not stay behind to try to put the fire out
- Tell everyone else in your home about the fire and get everybody to leave.
- Close all doors in your flat on the way, including the front door and leave the building
- Do not use the lift
- Call the fire service
- Wait for the fire service to arrive safely outside the building

This building is designed to contain fire and smoke in the area where the fire breaks out for a period of time.

If a fire breaks out in any other part of the building:

- Please stay within your flat unless you feel that your safety or your safe escape route is threatened.
- You must leave immediately if instructed to do so by the fire and rescue service.

You should leave immediately via a stairwell if fire or smoke affects any part of your flat. If you have any doubts or concerns, leave the building.

5.3 Persons Requiring Assistance

If you, or anyone else in your household feel that you would require assistance to evacuate the building please contact the Building Safety Team at your earliest convenience on 01484 414886 or email HNFire@kirklees.gov.uk.

6 Fire Safety Advice

To help keep you safe in your home, we have put together some simple fire safety points of advice below.

6.1 Smoke and heat alarms

- Test alarms monthly by pressing the 'Test' button
- If your alarm begins to intermittently beep (indicating low battery), or if you have concerns about your alarms, please contact [Housing Repairs](#) which is available in the My Kirklees Account. To access your housing repairs account, you will need to register or log into your My Kirklees Account. My Kirklees Account allows access to a range of services online - 24 /7 - all in one place and with one password.
- Any issues with alarms can also be reported on the following numbers:
- **8am to 6pm** - call Housing Repairs on [01484 414800](tel:01484414800).
- **6pm to 8am** - call Out of Hours Housing Repairs on [01484 414850](tel:01484414850).

6.2 Preventing fires

Cooking is the most common cause of house fires

- Never leave pans unattended, especially with oil or fat.
- Keep flammable items like cloths and packaging away from naked flames and always keep the area around the hob/oven clear.

Electrical safety

- Do not overload sockets or adapters; use only one plug per socket.
- Regularly inspect cables and plugs; discard and professionally replace any damaged ones.
- Unplug appliances at night or when not in use, except essentials like freezers.

Smoking

- Use suitable ashtrays, fully extinguish cigarettes before disposing of them.
- Don't smoke in bed.
- Do not smoke in communal areas.

Candles and air fresheners

- Place candles on stable, non-flammable holders.
- Keep away from curtains and furniture.
- Don't leave candles unattended.
- Only switch on air fresheners for a maximum 4 hours at a time

Portable heaters

- Keep at least 1m clear space around the heater and never use them for drying clothes.
- Portable gas appliances are not permitted in your home.

Charging devices (phones, laptops, e-bikes, e-scooters, e-cigarettes)

- Use correct chargers.
- Follow manufacturer guidelines.
- Don't charge appliances overnight or on soft furnishings.
- Do not charge appliances in an escape route including hallways, landings and stairwells

6.3 Escape planning and routine checks

- Create and practice a fire escape plan, from each room, and designate a safe meeting place.
- Keep escape routes and exits clear, and ensure keys are accessible. Spare keys are good to have in the bedroom.
- On an evening, close internal doors to slow the spread of fire and smoke. Make sure cooker and heaters are off and unplugged (except essential appliances), extinguish cigarettes and candles and unplug unnecessary electronics.

6.4 Family support and additional needs

- Teach children about fire risk, what the alarm sounds like, and emergency procedures.
- Installation of specialist alarms are available (e.g. vibrating pad for under pillow, visual aid by way of a light source). If you require any support, contact us at Resident.firesafety@kirklees.gov.uk.
- You can contact your local fire service to request a non-judgmental "Safe and Well" visit, they may be able to provide tailored advice and install free alarms www.westyorksfire.gov.uk/safe-and-well-visits.

6.5 Summary Checklist

- Test smoke/heat alarms monthly
- Cooking vigilance: stay present and keep cooking area clear from clutter
- Check cables and plugs regularly, don't overload sockets
- Unplug appliances at night (non-essentials)
- Responsibly use candle and heaters. Don't leave burning items unattended
- Properly extinguish smoking materials
- Plan, practise, and keep escape routes clear
- Close doors, unplug appliances, and secure escape paths before bed
- Cater to children, elderly, and disabled with suitable alarms and plans

- Book a free safe & well visit from the fire service www.westyorksfire.gov.uk/safe-and-well-visits

7 Further Information

7.1 QR codes and links to further information

More information on the regulations that we are required to meet can be found by scanning the QR codes below, or using the web addresses provided.

- [Regulatory Reform \(Fire Safety\) Order 2005](#)



- [Fire Safety Act 2021](#)



- [Fire Safety \(England\) Regulations 2022](#)



- [Building Safety Act 2022](#)



8 Who to contact

Person	Role	Contact Number	Email
David Ellison	Fire Safety – contact for fire safety matters		HNFire@kirklees.gov.uk
Sabrina Hussain	Tenant Engagement Officer – contact for engagement and feedback	01484 416400	Sabrina.hussain@kirklees.gov.uk
Customer Support	General enquiries	01484 414886	housing@kirklees.gov.uk
Repairs	Report a repair	01484 414800	Repairs can also be reported in your My Kirklees account