



YorkshireWater

Head of Planning Services
Kirklees Metropolitan District Council
P.O. Box B93
Civic Centre
Huddersfield
HD1 2JR

Your Ref: 2015/62/90435/E
Our Ref: R003880

Land Use Planning
Yorkshire Water Services Ltd
Midway
Western Way
Halifax Road
Bradford
BD6 2LZ

Tel: (01274) 691111

Fax:

For telephone enquiries ring:
Z Fayyaz on (01274) 692072

E-mail Zaffer.Fayyaz@yorkshirewater.co.uk

14th December 2015

Dear Sir/Madam,

Parkham Foods Ltd, 22 Halifax Road, Liversedge - Erection of 14 dwellings with integral garages -

Further to the planning consultation dated 10th April 2015.

Yorkshire Water has no objection in principle to:

- i) The proposed separate systems of drainage on site and off site.
- ii) The proposed point of discharge of foul water to the respective public sewer.

as submitted on drawing 8731-002 (revision A) dated 15/10/2015 that has been prepared by Sanderson.

It is noted that the submitted drawing shows surface water proposed to be drained to watercourse.

The developer should also note that the site drainage details submitted have not been approved for the purposes of adoption or diversion. If the developer wishes to have the sewers included in a sewer adoption/diversion agreement with Yorkshire Water (under Sections 104 and 185 of the Water Industry Act 1991), they should contact our Developer Services Team (tel 0345 120 84 82, fax 01274 303 047) at the earliest opportunity. Sewers intended for adoption and diversion should be designed and constructed in accordance with the WRc publication 'Sewers for Adoption - a design and construction guide for developers' 6th Edition, as supplemented by Yorkshire Water's requirements.

Yours faithfully

Zaffer Fayyaz
Planning & Development