

**Town and Country Planning Act 1990
Application for Permission to Develop Land**

Response from Pollution & Noise Control

PNC Reference No:	WK/201607448
Name of Planning Officer dealing with the matter:	Stuart Daniel
Application Number:	2016/62/91055/E
Proposed Development:	Part demolition, conversion and extension of existing buildings to 9 residential units with associated car parking.
Location:	Dean Bottom Works, Dene Bottom, Kirkburton, Huddersfield, HD8 0PW
Date Required By Planning:	3rd May 2016

COMMENTS
<p><u>Contaminated Land</u></p> <p>CLC1 <i>Submission of a Preliminary Risk Assessment (Phase 1 Report)</i> Development shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) has been submitted to and approved in writing by the local planning authority.</p> <p>CLC2 <i>Submission of an Intrusive Site Investigation Report (Phase II Report)</i> Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) development shall not commence until a Phase II Intrusive Site Investigation Report has been submitted to and approved in writing by the local planning authority.</p> <p>CLC3 <i>Submission of Remediation Strategy</i> Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) development shall not commence until a Remediation Strategy has been submitted to and approved in writing by the local planning authority. The</p>

Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

CLC4 *Implementation of the Remediation Strategy*

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report is identified or encountered on site, all works on site (save for site investigation works) shall cease immediately and the local planning authority shall be notified in writing within 2 working days. Unless otherwise agreed in writing with the local planning authority, works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the local planning authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

CLC5 *Submission of Validation Report*

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Validation Report shall be submitted to the local planning authority. Unless otherwise agreed in writing with the local planning authority, no part of the site shall be brought into use until such time as the remediation measures for the whole site have been completed in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Validation Report in respect of those remediation measures has been approved in writing by the local planning authority.

CLC 7 Footnote to be applied to all applications

All contamination reports shall be prepared in accordance with CLR11, PPS23 and the Council's Advice for Development documents or any subsequent revisions of those documents.

Noise

Before the development is first brought into use all works which form part of the sound attenuation scheme as specified in the Noise Report dated 15 January 2014 produced by S&D Garritt Ltd :-

- I. shall be completed; and
- II. written evidence to demonstrate that the specified noise levels have been achieved shall be submitted to and approved in writing by the local planning authority.

If it cannot be demonstrated that the noise levels specified in the aforementioned Noise Report have been achieved then a further scheme shall be submitted for the written approval of the local planning authority incorporating further measures to achieve those noise levels.

All works comprised within those further measures shall be completed and written evidence to demonstrate that the aforementioned noise levels have been achieved shall be submitted to and approved in writing by the Local Planning Authority before the development is first brought into use.

Sustainable Transport

Paragraph 35 of the national Planning Policy guidance states that "Plans should protect and exploit opportunities for the use of sustainable transport modes for the movement of goods or people. Therefore, developments should be located and designed where practical to.....incorporate facilities for charging plug-in and other ultra-low emission vehicles.."

We would like this development to encourage the use of ultra-low emission vehicles such as electric vehicles therefore we would like the following placed as a condition.

Sustainable Transport Condition

Before development commences, a scheme to show how the development shall incorporate facilities for charging plug-in electric vehicles shall be submitted to and approved in writing by the LPA. All works which form part of the approved scheme shall be completed prior to occupation of the development.

Footnote:

We would be satisfied with 1 charging point per unit (dwelling with dedicated parking) or 1 charging point per 10 spaces (unallocated parking).

Construction Site Footnote

To minimise noise disturbance at nearby premises it is generally recommended that activities relating to the erection, construction, alteration, repair or maintenance of buildings, structures or roads shall not take place outside the hours of:

07.30 and 18.30 hours Mondays to Fridays

08.00 and 13.00hours , Saturdays

With no working Sundays or Public Holidays

In some cases, different site specific hours of operation may be appropriate.

Under the Control of Pollution Act 1974, Section 60 Kirklees Environment and Transportation Services can control noise from construction sites by serving a notice. This notice can specify the hours during which work may be carried out.

Date:	4 May 2016	Officer:	Alexandra Garry Ext 70832
--------------	------------	-----------------	---------------------------