

**Town and Country Planning Act 1990
Application for Permission to Develop Land**

Response from Pollution & Noise Control

PNC Reference No:	WK/201615083
Name of Planning Officer dealing with the matter:	Beatrice Kunaka
Application Number:	2016/91648
Proposed Development:	Erection of 8 x 8m high lighting columns adjacent to rugby pitch and training area
Location:	Newsome Panthers, Hall Bower Lane, Hall Bower, Huddersfield, HD4 6RR
Date Required By Planning:	11th August 2016

COMMENTS

I have reviewed the application and have some concerns in relation to the lighting affecting the amenity of residential premises. I recommend the following condition:

1. Before development commences a scheme which indicates the measures to be taken for the control of any glare or stray light arising from the operation of artificial lighting shall be submitted to and approved in writing by the Local Planning Authority. Thereafter the artificial lighting shall be operated in accordance with the approved scheme.

Note – British Standard EN12193:2007 for Light and Lighting Sports Lighting advises a level 75 lux for the maintained lighting level for use of rugby pitches used for low level club competition.

2. The floodlights hereby approved shall not be operated between the hours of 2100 and 0900 on any day of the week

Footnote

To reduce problems of glare from floodlights and security lights, such lighting should be installed and maintained in accordance with the “ Guidance Notes for the Reduction of Light Pollution” produced by the Institution of Lighting Engineers (telephone 01788 576492).

Date:

11 8 2016

Officer:

Andrew Robinson Ext 860 6435