



**The Coal
Authority**



INVESTOR IN PEOPLE



RTPI
Learning Partner

200 Lichfield Lane
Berry Hill
Mansfield
Nottinghamshire
NG18 4RG

Tel: 01623 637 119 (Planning Enquiries)

Email: planningconsultation@coal.gov.uk

Web: www.gov.uk/coalauthority

For the Attention of: Ms E Thompson – Case Officer
Kirklees Council

[By Email: DC.Admin@kirklees.gov.uk]

7 February 2017

Dear Ms Thompson

PLANNING APPLICATION: 2016/62/94216/E

Change of use of workshop to dwelling - Adj Canary Hall, Drub Lane, Drub, Cleckheaton, BD19 4BZ

Thank you for your notification of 26 January 2017 seeking the views of The Coal Authority on the above planning application.

The Coal Authority is a non-departmental public body sponsored by the Department for Business, Energy & Industrial Strategy. As a statutory consultee, The Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority Response: Material Consideration

I have reviewed the proposals and confirm that the application site falls within the defined Development High Risk Area; therefore within the application site and surrounding area there are coal mining features and hazards which need to be considered in relation to the determination of this planning application.

The Coal Authority records indicate that the site is in an area of likely historic unrecorded underground coal mine workings at shallow depth.

The Coal Authority notes that the application is for change of use of a workshop to a dwelling. Unfortunately there are no elevational plans or existing floorplans on the LPA website and the Coal Authority therefore assumes that this submission is a pure change of use with no extensions or additions required to facilitate this change. The Coal Authority comments are made on this basis.

The Coal Authority Recommendation to the LPA

As you will be aware, the Coal Authority's general approach in cases where development is proposed within the Development High Risk Area is to recommend that the applicant obtains coal mining information for the application site and submits a Coal Mining Risk Assessment to support the planning application.

However, when considering this particular submission it appears from the information available on the LPA website that this is a change of use application with no operational development required that would intersect the ground and could therefore present risks to the coal mining features. Therefore we do not consider that a Coal Mining Risk Assessment is necessary for this proposal and **do not object** to this planning application.

In the interests of public safety, however, the Coal Authority would recommend that, should planning permission be granted for this proposal, the following wording is included as an Informative Note within the Decision Notice:

The proposed development lies within an area that has been defined by the Coal Authority as containing potential hazards arising from former coal mining activity. These hazards can include: mine entries (shafts and adits); shallow coal workings; geological features (fissures and break lines); mine gas and previous surface mining sites. Although such hazards are seldom readily visible, they can often be present and problems can occur in the future, particularly as a result of development taking place.

It is recommended that information outlining how the former mining activities affect the proposed development, along with any mitigation measures required (for example the need for gas protection measures within the foundations), be submitted alongside any subsequent application for Building Regulations approval (if relevant).

Any intrusive activities which disturb or enter any coal seams, coal mine workings or coal mine entries (shafts and adits) requires a Coal Authority Permit. Such activities could include site investigation boreholes, digging of foundations, piling activities, other ground works and any subsequent treatment of coal mine workings and coal mine entries for ground stability purposes. Failure to obtain a Coal Authority Permit for such activities is trespass, with the potential for court action.

Property specific summary information on past, current and future coal mining activity can be obtained from: www.groundstability.com or a similar service provider.

If any of the coal mining features are unexpectedly encountered during development, this should be reported immediately to the Coal Authority on 0345 762 6848. Further information is available on the Coal Authority website at: www.gov.uk/coalauthority

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours sincerely

Melanie Lindsley

Melanie Lindsley *BA (Hons), DipEH, DipURP, MA, PGCertUD, PGCertSP, MRTPI*
Planning Liaison Manager

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.