

Hannah Halstead

From: John Ritchie
Sent: 24 April 2017 14:29
To: DCAdmin
Subject: FW: 2016/94235 Consultation response - Flood management

From: Gemma Snell
Sent: 24 April 2017 14:25
To: John Ritchie
Subject: RE:

Hi John,

Granny Lane – No objection to the discharge of condition 11.

Commercial Road - No calculations have been submitted to demonstrate the proposal provides the required 30% reduction in existing run-off rates or to demonstrate that the proposed attenuation tank is therefore sized appropriately. Further information is required.

Thanks,

Gemma.