

**Town and Country Planning Act 1990  
Application for Permission to Develop Land**

**Response from Pollution & Noise Control**

<b>PNC Reference No:</b>	WK/201803881
<b>Name of Planning Officer dealing with the matter:</b>	Matthew Woodward
<b>Application Number:</b>	2017/90620
<b>Proposed Development:</b>	Hybrid application- Planning application for demolition of existing buildings and erection of 2no workshop and ancillary office building (B1c/B8 use class) comprising a floor area of 800m2 including mezzanine space, parking, access details...
<b>Location:</b>	Dobroyd Mills, Hepworth Road, Jackson Bridge, Holmfirth, HD9 1AF
<b>Date Required By Planning:</b>	07/03/2018

<b>COMMENTS</b>
<p>This application has changed again from the previous layout/proposal commented on by myself in December 2018. The significant change is the demolition of the 4 storey mill building which was to be retained for a mixture of B1c and C3 uses.</p> <p>The current application is for 2 new workshop/ancillary office space buildings (B1c/B8 use classes) and outline planning for 75 dwellings.</p> <p>Overall I have no objection this development being granted planning permission subject to conditions regarding Land Contamination, Air quality, hours of use/delivery of the B1c/B8 units and Construction/Demolition site hours, due to adjacent residential property on Hepworth Road.</p> <p><b>Contaminated Land</b></p> <p>I have studied the submitted report (ARC Environmental Ltd dated April 2016 ref: 16-202), and agree with its contents and conclusions. I therefore recommend that the following</p>

conditions are applied to any consent granted:

CLC2 Submission of an Intrusive Site Investigation Report (Phase II Report) Development shall not commence until a Phase II Intrusive Site Investigation Report has been submitted to and approved in writing by the local planning authority.

CLC3 Submission of Remediation Strategy Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) development shall not commence until a Remediation Strategy has been submitted to and approved in writing by the local planning authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

CLC4 Implementation of the Remediation Strategy Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered [in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report] is identified or encountered on site, all works on site (save for site investigation works) shall cease immediately and the local planning authority shall be notified in writing within 2 working days. Unless otherwise agreed in writing with the local planning authority, works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the local planning authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

CLC5 Submission of Validation Report Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Validation Report shall be submitted to the local planning authority. Unless otherwise agreed in writing with the local planning authority, no part of the site shall be brought into use until such time as the remediation measures for the whole site have been completed in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Validation Report in respect of those remediation measures has been approved in writing by the local planning authority.

CLC 7 Footnote to be applied to all applications All contamination reports shall be prepared in accordance with CLR11, PPS23 and the Council's Advice for Development documents or any subsequent revisions of those documents.

### **Air Quality**

This development has been assessed in accordance with the West Yorkshire Low Emission Strategy Planning Guidance. The size of the development is more than that of prescribed values set out in this document and also meets additional set criteria, which is why it is regarded as a major development.

We therefore require the following condition:

- Install 1 charging point per unit (dwelling with dedicated parking) or 1 charging point per 10 spaces (unallocated parking)
- Install 1 charging points in 10% of parking spaces or if agreed with the planning authority may be phased with 5% initial provision and the remainder at an agreed trigger level
- Produce a Travel Plan including mechanisms for discouraging high emission vehicle use and encouraging modal shift (i.e. public transport, cycling and walking) as well as the uptake of low emission fuels and technologies
- All commercial vehicles should comply with current or the most recent European Emission Standards from scheme opening, to be progressively maintained for the lifetime of the

development •Upon occupation of the site Fleet Operators must provide a strategy for reducing emissions, which must be agreed with by the local authority.

•Provide a Full Air Quality Impact Assessment including calculating the monetary damages from the development. The monetary value of the damages should be reflected in money spent on low emission mitigation measures.

### **B1c and B8 Hours of use**

Unless otherwise agreed in writing with the LPA no activities shall be carried out on the premises, including deliveries to or dispatches from the premises, outside the hours of 0730 and 1800 Monday to Friday and 0800 to 1300 Saturdays. No activities shall take place on Sundays or Bank Holidays.

Reason: To protect the amenity of nearby residential properties.

### **Hours of Construction**

To minimise noise disturbance at nearby existing residential premises it is generally recommended that activities relating to the erection, construction, alteration, repair or maintenance of buildings, structures or roads shall not take place outside the hours of: 07.30 and 18.30 hours Mondays to Fridays 08.00 and 13.00hours , Saturdays With no working Sundays or Public Holidays In some cases, different site specific hours of operation may be appropriate. Under the Control of Pollution Act 1974, Section 60 Kirklees Environment and Transportation Services can control noise from construction sites by serving a notice. This notice can specify the hours during which work may be carried out.

<b>Date:</b>	05-03-2018	<b>Officer:</b>	Kevin Moore 01484 221000 ext 70841
--------------	------------	-----------------	------------------------------------