

John Ritchie

From: Valley Properties <vproperties@supanet.com>
Sent: 09 May 2017 13:50
To: John Ritchie
Subject: RE: 2017/91095 - 24 The watermill, Slaithwaite
Attachments: AR_500E4_SILEO_AXIAL_FAN.pdf

Hi John

I have included a copy of the data sheet for the extract fan that is fitted on the ventilation system at the Watermill. I can also confirm that other than the fact that the ductwork terminates above any opening windows in the nearby vicinity there are no other odour control measures in place as the cooking equipment and style of cooking are of low non offensive odour emission.

There are no attenuation measures on this system.

The ductwork is spiral galvanised steel in 500 dia and is installed as per the sketches attached.

Regards

Andrew Smith

VALLEY PROPERTIES

From: John Ritchie [<mailto:John.Ritchie@kirklees.gov.uk>]
Sent: 03 April 2017 11:30
To: 'vproperties@supanet.com' <vproperties@supanet.com>
Subject: 2017/91095 - 24 The watermill, Slaithwaite

I write with reference to the above application to discharge planning condions.

You have submitted an elevational drawing to satisfy condition 3. This condition requires additional details of the methods of treatments of emissions and filters to remove odours and control noise emissions. The application cannot be validated until such details have been received.


The application will be held for 21 days after which time if the details have not been received the application and fee will be returned to you.

John Ritchie

Senior Planning Officer - Development Management
Investment and Regeneration Service
Kirklees Planning, PO BOX B93, Civic Centre III, Huddersfield, HD1 2JR
É 01484 221000
E john.ritchie@kirklees.gov.uk
W www.kirklees.gov.uk/planning



The information contained in this e-mail, and any files transmitted with it, is confidential to the intended recipient(s). The dissemination, distribution, copying or disclosure of this message or its contents is prohibited unless authorised by the sender. If you receive this message in error, please immediately notify the sender and delete the message from your system.



[Website](#) | [News](#) | [Email Updates](#) | [Facebook](#) | [Twitter](#)

This email and any attachments are confidential. If you have received this email in error – please notify the sender immediately, delete it from your system, and do not use, copy or disclose the information in any way. Kirklees Council monitors all emails sent or received.