

Hannah Halstead

From: Nick Goddard
Sent: 03 May 2017 14:33
To: DCAdmin
Subject: 2017/91214 - Heaton Avenue School

Hi Sarah

The proposed layout has not taken into account the previous comments from the Tree Officer to take into account the street trees along the perimeter. No information has been provided in the form of an Arboricultural Impact Assessment in accordance with BS5837:2012.

I would need to see information to show that the root protection areas, crown spreads and shade patterns have been taken into account when designing this scheme and that it is implementable without causing damage to the trees on site.

At present I cannot support this application.

Kind regards

Nick Goddard
Arboricultural Officer

T: 01484 414909

Email: trees.planning@kirklees.gov.uk

Web: www.kirklees.gov.uk/trees

See our new [pre-application advice service](#)

Planning
Investment and Regeneration Service
PO Box B93
Civic Centre 3
off Market Street
Huddersfield
HD1 2JR

This email and any attachments are confidential. If you have received it in error – notify the sender immediately, delete it from your system, and do not use, copy or disclose the information in any way. Kirklees Council monitors all emails sent or received.