



INFORMATION WITHIN THIS DRAWING IS NOT NECESSARILY PROTECTED TO SCALE. ALWAYS USE FIGURED DIMENSIONS AND CO-ORDINATES - IF IN DOUBT, ASK.				
NOTES				
1. ESTATE ROAD SPECIFICATION				
SURFACE COURSE: 30mm thk. - 6mm size dense blumium macadam surface course complying with BS 4887.				
BINDER COURSE: 40mm thk. - 20mm size dense blumious binder course complying with BS 4887.				
BASE (ROADBASE): 85mm thk. - 20mm size dense blumious base complying with BS 4887.				
SUB-BASE: 350mm thk. - Type 1 granular sub-base. Must be free from extraneous matter. Weeds must be removed and the sub-grade sprayed with total weedkiller.				
2. ROAD SPECIFICATION - SHARED SURFACE				
SURFACE COURSE				
SUB-BASE				
350mm thk. - Type 1 granular sub-base to Specification for Highway Works. Must be free from extraneous matter. Weeds must be removed and the sub-grade sprayed with total weedkiller.				
3. FOOTPATH SPECIFICATION				
SURFACE COURSE: 25mm thk. - 6mm size dense blumious surface course.				
BINDER COURSE: 40mm thk. - 20mm size dense blumious binder course.				
SUB-BASE: 100mm thk. - Type 1 granular sub-base. Must be free from extraneous matter. Weeds must be removed and the sub-grade sprayed with total weedkiller.				
4. VEHICULAR CROSSING SPECIFICATION				
SURFACE COURSE: 25mm thick 6mm size dense blumious macadam.				
BINDER COURSE: 40mm thick 20mm size dense blumious macadam.				
SUB BASE: 100mm thick 1 granular sub-base.				
SUB BASE: 100mm thick 1 granular sub-base.				
Serving more than 2 dwellings, 300mm thick type 1 granular sub base.				
Kerb base: 25mm.				
3. GENERAL NOTES				
The formation, whether in cut or fill, shall be prepared, profiled and THICKENED, COMPACTED as required by clauses 6/12 and 6/16 of the Over excavation below formation is to be bedfilled with Type 1 granular sub-base material, well compacted in layers not exceeding 220mm.				
All workmanship and specification to be in accordance with local authorities requirements.				
REV				
A				
First Issue.				
DESCRIPTION				
SIG				
CHK				
DATE				
MILLER HOMES				
CROSS LANE,				
SCHOLLES, HOLMFIRTH				
HIGHWAYS LAYOUT				
Eastwood & Partners				
CONSULTING ENGINEERS				
St. Andrew's House				
23 Kingfield Road				
S11 9AS				
Tel. 0114 255 4554				
Fax. 0114 255 4330				
mail@eastwoodandpartners.com				
www.eastwoodandpartners.com				
SCALE WHEN PLOTTED AT 1:1				
DRAWING STATUS				
1:500				
PRELIMINARY				
DRAWN (CHECKED)				
DATE				
DRAWING NUMBER				
REV				
R1				
CH				
11.04.17				
40600/006				
E				