

Lindsay Haigh

From: Olivia Roberts
Sent: 14 February 2018 10:56
To: DCAdmin
Subject: 2017/94280 - 39 Pollard Avenue

Hi

Could this please be indexed as a consultation response in relation to application 2017/94280

Thank you

Olivia

From: Jamie Turner
Sent: 09 February 2018 10:02
To: Olivia Roberts <Olivia.Roberts@kirklees.gov.uk>
Subject: 2017/94280 Pollard Avenue

Hi Olivia,

Further to our conversation, for the hardstanding at the front of the dwelling to be acceptable for two cars, the minimum dimensions required would be 5.0m x 5.0m. Although this appears to be achievable, the area on the submitted plan is narrower than 5.0m. If this was amended, I'd be happy to support the application.

Kind Regards,

Jamie