

Lindsay Haigh

From: Nigel Hunston
Sent: 19 July 2018 14:33
To: John Ritchie
Subject: 2018/90954: Discharge of conditions; 18 Manor Road, Farnley Tyas

Condition 3 Materials

No details have been provided other than a photo. I have no objection to their use but product names should be sought.

Condition 9 boundary details

External walls are shown to be post and rail or is it the close boarded fence. Comfortable with the stone walls but clarification over the rear fencing should be sought.

Condition 22 windows

This is not clear. The drawing is annotated as plots 3-8 but only shows plots 1-2. The supporting documents show a Glenfied Window brochure which suggests a full sash which is fine. Which are we using here and on what plots

Condition 25. Painting details

Acceptable

Condition 26. Door details

Acceptable

Condition 27. Stone window details

Acceptable

Condition 31. Garage doors

Acceptable

Get [Outlook for iOS](#)