

DCAdmin

From: Nick Goddard
Sent: 03 January 2019 10:53
To: DCAdmin
Subject: 2018/94068 - 24 Butterley Lane, New Mill

Dear Laura

No tree information has been provided with the application making it difficult to assess. The adjacent trees are protected by a TPO and therefore their protection and long term viability is important. There are two large trees in close proximity to the location of the new garage and it is unclear how this is to be constructed without causing damage to these adjacent trees.

The proposed garage is within the root protection area of the trees and therefore normal foundations for the garage may cause significant damage. I would like to see details of how the garage is to be constructed and how the adjacent trees will be protected during this work. Could you request an Arboricultural Method Statement and Tree Protection Plan to be supplied in order to address this?

Kind regards

Nick Goddard
Tree Officer

Planning Services (Tree Section)
Kirklees Council
Investment and Regeneration
PO Box B93, Civic 3
Huddersfield
HD1 2JR

T: 01484 414909
E: trees.planning@kirklees.gov.uk

This email and any attachments are confidential. If you have received it in error – notify the sender immediately, delete it from your system, and do not use, copy or disclose the information in any way. Kirklees Council monitors all emails sent or received.