

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2019/91891 - Dewsbury Moor ARLFC, Heckmondwike Road, Dewsbury Moor, Dewsbury, WF13 3NU		
Discharge conditions 6 (retaining walls), 7-10 (Phase II and Remediation) on previous permission 2016/91414 for erection of extensions and alterations		
Date Responded: 27 Apr 2019	Responding Officer: Richard Hume	Responding Ref: WK/201915951
<p>In our consultation response for the original application we did not recommend any conditions. It is noted that a Coal Mining Risk Assessment was submitted with the original application which advised that there was a possibility of shallow coal seams being worked beneath the site. It recommended further investigation regarding the potential impact possible shallow mining on surface stability. Conditions 7 to 10 have therefore been required in relation to the coal mining legacy issues, and would appear to be in particular for the purposes of assessing ground stability issues which are outside the remit of Environmental Health.</p> <p>It is noted in the in the information submitted with this discharge of condition application is a borehole log for 12 Oct 2018 by Ground Support Services (UK) Ltd. This details four boreholes at the site, three to 15m depth and one to 30m. Coal seams are not identified in any of these.</p> <p>Recommendations</p> <p>We did not originally have any contaminated land concerns, the new information provided does not change the situation. Therefore Environmental Health do not require any information regarding contaminated land aspects for this site. We therefore have no objections to conditions 7 to 10 being discharged in relation to contaminated land issues.</p> <p>However, other agencies such as the Coal Authority may wish to comment on the information recently submitted.</p>		