



YorkshireWater

Head of Planning Services
Kirklees Metropolitan District Council
P.O. Box B93
Civic Centre
Huddersfield
HD1 2JR

Your Ref: 2019/91974
Our Ref: V010827

Yorkshire Water Services
Developer Services
Pre Development Team
PO Box 52
Bradford
BD3 7AY

For telephone enquiries ring :

Olivia S Webster
Development Technician
Developer Services on 754247

21st October 2019

Dear Sir/Madam,

Moldgreen Working Mens Club , 15 Church Street, Moldgreen, Huddersfield - Demolition of working mens club and erection of 12 apartments

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Waste Water

Based on the information submitted, Yorkshire Water has no objection to:

The Drainage Foul Sewerage Assessment prepared by JNP Group (Report dated 2019) is acceptable.

In summary, the report states that:

Surface water will discharge to public combined sewer via storage with restricted discharge (of 3.5 litres/second)

Yours faithfully

Olivia S Webster
Development Technician
Developer Services

