

Consultation Response from KC Environmental Health – Pollution & Noise Control		
2019/91981		
Finthorpe Grange, Finthorpe Lane, Almondbury, Huddersfield, HD5 8TU		
Listed Building Consent for installing air source heat pumps		
Date Responded: 30 September 2019	Responding Officer: Alexandra Garry	Responding Ref: WK/201919147
NC8 Noise Report required for proposed noise generating use close to existing noise sensitive premises - Condition Before installation a noise assessment report by a suitably competent person shall be submitted to and approved in writing by the Local Planning Authority. The report shall include:- a) an assessment of all of the noise emissions from the proposed development b) details of existing background and predicted future noise levels at the boundary of noise sensitive premises (15 Finthorpe Lane). c) a written scheme of how the occupants of the above mentioned noise sensitive premises will be protected from noise from the proposed development including details of all necessary noise attenuation The development shall not be brought into use until all works comprised within the measures specified in the approved report have been carried out in full and such works shall be thereafter retained.		