

Consultation Response from KC Environmental Health – Pollution & Noise Control
2019/93284
Clayton West United Reformed Church, Church Lane, Clayton West, Huddersfield, HD8 9LY
Alterations to convert former church to 6 dwellings
**Date Responded:
5 November 2019**
**Responding Officer: Kevin
Ellam**
**Responding Ref:
WK/201922418**

I have reviewed the information submitted by the applicant and recommend the following conditions:

AIR QUALITY

In an application of this nature it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary.

Electric Vehicle Charging Points – Condition

Before the electrical system is installed a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:-

- A Standard Electric Vehicle Charging point (of a minimum output of 16A/3.5kW) for each residential unit that has a dedicated parking space
- One Standard Electric Vehicle Charging Point for every 10 unallocated residential parking spaces

Buildings and parking spaces that are to be provided with charging points shall not be brought into use until the charging points are installed and operational. Charging points installed shall be retained thereafter.

Electric Vehicle Charging Points – Footnote

- A Standard electric vehicle charging point is one which is capable of providing a continuous supply of at least 16A (3.5kW). A 32A (7kW) is however more likely to be futureproof
- Standard charging points for single residential properties that meet the requirements specified in the latest version of “*Minimum technical specification - Electric Vehicle Homecharge Scheme (EVHS)*” by the Office for Low Emission Vehicles will be acceptable. Basically, charging points that provide Mode 3 charging with a continuous output of least 16A (3.5kW) and have Type 2 sockets would be acceptable.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity.
- The installation must comply with all applicable electrical requirements in force at the time of installation.

Construction Site Working Times - Condition

Noisy construction related activities shall not take place outside the hours of:

07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00hours , Saturdays

With no noisy activities on Sundays or Public Holidays

Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists, or is likely to occur or recur. Failure to comply with a notices served using the above mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.