

Consultation Response from KC, Lead Local Flood Authority
2019/93464 Land at, Lancaster Lane, Brockholes, Holmfirth, HD9 7TL
Reserved matters application for erection of 9 dwellings pursuant to outline permission 2016/90146
Date Responded: 15/11/2023. Responding Officer: Martin Stephenson Responding Ref: 6
<u>Previous response by the LLFA</u> Dated 03/02/2022 for application 2019/93464 Dated 09/02/2023 for application 2019/93464 Dated 10/10/2023 for application 2019/93464 <u>Documents reviewed by the LLFA:</u> AVIE: Document reference, Causeway Calculations, dated 26/10/2023. Drawing No. P3345-100 Private Drainage Layout, Rev P04 dated 27/10/2023. Drawing No. P3345-103 Proposed Impermeable Areas, Rev P02 dated 27/10/2023. Drawing No. P3345-101 Standard Details, Rev P03 dated 27/10/2023. <u>Drainage Summary</u> The information on the drawings and hydraulic calculations is now consistent and the private drainage set out on Drawing P3345-100, Revision 4 and associated drawings/calculations is now acceptable to the LLFA. Kirklees Flood Management and Drainage as the Lead Local Flood Authority, SUPPORTS this application and has no recommended drainage conditions.