



KEY TO FIRE DETECTION SYMBOLS

- FD30S 1/2hr. fire resistant self closing door with  
intumescent strips and smoke seals
- Ⓢ automatic fire detection – heat detector
- Ⓢ automatic fire detection – smoke detector
- N3 notice on door  
"THIS DOOR TO BE KEPT LOCKED SHUT  
WHEN NOT IN USE"
- EL Emergency lighting with directional  
arrow towards exit
- N5 notice on door  
"FIRE EXIT – KEEP CLEAR"
- N7 notice on door  
"FIRE DOOR – KEEP SHUT"
- E "FIRE EXIT" sign
- IP fire alarm indicator panel
- ⦿ fire alarm call point
- 🔊 audible warning device
- emergency light point
- 🧯 fire blanket
- Min 30mins fire resisting construction

1:50



EL - Denotes emergency lighting  
with directional arrow to exit.  
Emergency lighting to be to  
B.S. 5266-1:2011

Remainder of first floor and all  
of ground floor unaffected by  
proposals.

