

Consultation Response from KC Environmental Health – Pollution & Noise Control
2020/90133 Chapel Royd, Emley, Huddersfield, HD8 9GN
Erection of extension to garage and front and rear dormer windows
Date Responded:
2nd March 2020
Responding Officer:
Hannah Kent
Responding Ref:
WK/202002332

I have reviewed this application and supporting documents and comment as follows:

This site has been identified on our mapping system as potentially contaminated land without further detail. Contaminated land conditions are therefore necessary.

CLC6 Reporting of Unexpected Contamination - Condition

In the event that contamination not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. Unless otherwise approved in writing by the Local Planning Authority, No part of the site shall be brought into use until such time as the site has been remediated in accordance with the approved Remediation Strategy and a Validation Report in respect of those works has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC 7 Contaminated land - Footnote

All contamination reports shall be prepared in accordance with *Model Procedures for the Management of Land Contamination – Contaminated Land report 11* (CLR11), National Planning Policy Framework (NPPF) and the Council's Advice for Development documents or any subsequent revisions of those documents.

With Regards

Hannah Kent