

Consultation Response from KC Environmental Health – Pollution & Noise Control		
2020/90441		
Bradley Service Station, Bradley Road, Bradley, Huddersfield, HD2 1QD		
Discharge conditons 3, 6, 7, 18 on previous permission 2019/92233 for erection of petrol filling station, including new shop building, canopy, jet-wash and below ground storage tanks.		
Date Responded: 13 February 2020	Responding Officer: Kevin Ellam	Responding Ref: WK/202003872
I have reviewed the lighting report by Bever Innovations dated 4 December 2019(Ref:SBO04122019-Pennine-V1) but I am unable to discharge condition 6 on previous permission 2019/92233 based on the information provided. The report refers to perpendicular lighting levels but gives no indication what it is perpendicular to. I also require the horizontal illuminance levels for the site (with some reference to guidance to demonstrate that they are appropriate and not excessive) and the vertical illuminance levels that will be caused at any nearby windows to demonstrate that it's not excessive. The times of operation for the lighting are not apparent in the report either.		