

Consultation Response from KC Environmental Health – Pollution & Noise Control		
2020/90682		
Croft Medical Centre, 5 Cobcroft Road, Fartown, Huddersfield		
Discharge conditions 5 (ventilation) and 6 (boundary treatment) on previous permission 2014/90774 for erection of 2 storey medical centre with integral pharmacy and parking		
Date Responded: 11 June 2020	Responding Officer: Alexandra Garry	Responding Ref: WK/202014585
I have reviewed the additional information submitted by the applicant which includes the cumulative affect of the air conditioning units associated with the pharmacy. The report is satisfactory and concludes that noise levels from the development are below existing background levels by at least 9dB. Therefore I can recommend the discharge of Condition 5 of previous permission 2014/90774.		