



Click here to download pictures. To help protect your privacy, Outlook prevented automatic download of some pictures in this message.

From: Michael Chow [Michael@jade3architecture.co.uk]
To: 'Adam Martin'
Cc:
Subject: RE: 47-51 daisy hill

From: Adam Martin [<mailto:adam@novaacoustics.co.uk>]
Sent: 21 June 2020 14:24
To: Michael Chow
Cc: Harjoth Sekhon
Subject: Re: 47-51 daisy hill

Hi Both,

If the existing glazing as 4mm plate glass, the secondary glazing option would be 4mm Glass / 100mm Cavity / 6mm Glass.

Regards

—

Adam Martin

MSc, MIOA, MIET, MCIEH, MInstSce

Acoustic Consultant

DD: 0113 460 1038

Switch Board: 0330 043 1239



W: www.novaacoustics.co.uk

Leeds | Sheffield | Hull | Manchester | Liverpool | Newcastle Upon Tyne | Birmingham | Cambridge | London

NOVA Acoustics Ltd terms and conditions for all work undertaken can be found [HERE](#). At NOVA Acoustics Ltd we merit any and all comments received from our clients, take pride in providing an excellent service and place value on our ability to correct error. Should you wish to comment on any aspect of the service that I personally, or NOVA Acoustics Ltd as a whole, have given you, please reply through my e-mail address above. NOVA Acoustics Ltd does not accept legal responsibility for the contents of this message.

The recipient is responsible for verifying its authenticity before acting on the contents. Any views or opinions presented are solely those of the author and do not necessarily represent those of NOVA Acoustics Ltd.

NOVA Acoustics Ltd, Suite 13, 94 Amley Road, Leeds, LS12 2EJ. Registered in England No. 8884665. VAT Registration No. 183 0110 50.