

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2020/92337 - 6 Macaulay Street, Huddersfield HD1 2JY		
Erection of 6 street light columns		
Date Responded: 24 Aug 2020	Responding Officer: Richard Hume	Responding Ref: WK/202021710
No information has been provided regarding the specification for the lighting, the illuminance levels that the lighting will cause to the area to be illuminated and the proposals to ensure that glare from the lighting is minimised. This information is required to ensure that the lighting is not excessive and does not causes a problem. Recommended Condition LC1 External Artificial Lighting - Condition Before artificial lighting is brought into use a lighting scheme shall be submitted to and approved in writing by the Local Planning Authority. The scheme should include the following information: a) The proposed hours of operation of the lighting b) The location and specification of all of the luminaires c) The proposed design level of maintained average horizontal illuminance for the areas that needs to be illuminated. d) The predicted vertical illuminance that will be caused by the proposed lighting when measured at windows of any properties in the vicinity. e) The measures that will be taken to minimise or eliminate glare and stray light arising from the use of the lighting that is caused beyond the boundary of the site f) The methods of switching and controlling the lighting so that it is only operated at the permitted times and at times when it is required. The external artificial lighting shall be installed and operated thereafter in accordance with the approved scheme. Reason: To safeguard the amenities of the occupiers of nearby properties and promote sustainable development in accordance with part 2 and 15 of the NPPF and xxxxx of the Local Plan LF1 Artificial lighting - Footnote The proposed design levels of illuminance should be shown to be appropriate for the intended use by reference to appropriate guidance. Generally, to minimise problems of glare and stray light from external artificial lighting it should be installed and maintained in accordance with the <i>“Guidance Notes for the Reduction of Obtrusive Light”</i> by the Institution of Lighting Professionals: 2011 www.theilp.org.uk. The predicted levels of stray light must not exceed the recommended maximum levels given in Table 2 of this guidance for an Environmental Zone E3.		