




STRUCTURAL INSPECTION OF A TRADITIONAL BARN ON LAND AT 16 UPPER HOLME, SLAITHWAITE

This report is prepared for planning purposes only and is to read in conjunction with the existing plans accompanying the application.

The barn in question is the oldest in the range and is labelled as building no 6 on the submitted plans and is constructed out of stone walls and a stone tile roof. Although foundations are not likely to be present the walls are wide and solid and are generally in good structural condition with very little cracking, there is however some localised damage around some of the openings.



Roof covering appears in good order although a couple of slates have slipped, the roof structure appears sound, there is slight deviation in the ridge visible externally but not significant. Whilst internally the floors are concrete. From our inspections and surveys, we would confirm that the building is in our opinion generally in good condition and of sufficient integrity to form the basis for conversion. The building does have areas that require attention both have wall and roof issues which need addressing in the short term.

Princes House, 8 Princes Street, Harrogate, HG1 1HN



NOTE

This report is written to accompany a planning application and it must be used only for this purpose.