

Consultation Response from Strategic Waste**44 Westerley Lane, Shelley, Huddersfield HD8 8HP****Erection of single storey front extension and garage alterations**

Date Response 01.09.20

Responding Officer WT

REF 2020/92684

There is one closed landfill within 250m of application address.

Kc Ref 300 lies approximately 204m away, this area was last tipped on in 1999 with 20,000m³ of construction and excavation waste with a maximum depth of 4m.

The area is now used for agriculture and in 2003 shallow spike testing for LFG produced values of-

CH₄ 0.1% v/v**Co₂ 1.2% v/v**

**Wayne Thornton
Monitoring Officer
REF WT3233**