

Consultation Response from: KC Environmental Health (Pollution & Noise Control)
2020/92839 22, Aspen Close, Gomersal, Cleckheaton, BD19 4NY
Erection of single storey side and rear extensions
Date Responded:
4th November 2020

Responding Officer:
Rebecca Muff

Responding Ref:
WK/202030007

I have reviewed the application and supporting information and make the following comments and recommendations.

Contaminated Land

The on-site history of the proposed development indicates that there is the potential for ground contamination due to its past historical use as a former textile mill (our site ref: 81/2). As such the following conditions will be necessary.

Recommendations
CLC6 Reporting of Unexpected Contamination - Condition

In the event that contamination not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. Unless otherwise approved in writing by the Local Planning Authority, no part of the site shall be brought into use until such time as the site has been remediated in accordance with the approved Remediation Strategy and a Validation Report in respect of those works has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC 7 Contaminated land - Footnote

All contamination reports shall be prepared in accordance with guidance in *Land Contamination Risk Management (LCRM)*, National Planning Policy Framework (NPPF) and the Council's Advice for Development documents or any subsequent revisions of those documents.

CSC1 Construction Site Working Times - Condition

Noisy construction related activities shall not take place outside the hours of:

07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00 hours, Saturdays

With no noisy activities on Sundays or Public Holidays

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and **xxxxx** of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.