

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2020/92846 – r/o Midway House, 51 & 53, Huddersfield Road, Meltham, Holmfirth, HD9 4AF

Outline application for erection of residential development and demolition of outbuilding (within a Conservation Area)

Date Responded:
20 October 2020

Responding Officer:
Mohammed Nasim

Responding Ref:
WK/202026651

Comments

Outline planning permission is sought for two detached dwellings on land at the rear of Midway House. We would look to control the effects of any noise, dust etc. during the demolition and construction of the properties and so would ask for a condition requiring a Construction Environmental Management Plan to minimise any loss of amenity to neighbouring properties.

In an application of this nature it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary.

Recommended Conditions

CEMPC Construction Environmental Management Plan - Condition

Prior to development commencing, a Construction Environmental Management Plan (CEMP) shall be submitted to and agreed in writing with the Local Planning Authority. The plan shall describe in detail the actions that will be taken to minimise adverse impacts on occupiers of nearby properties by effectively controlling:

- Noise & vibration arising from all construction related activities. This should also include suitable restrictions on the hours of working on the site including times of deliveries.
- Dust arising from all construction related activities.
- Artificial lighting used in connection with all construction related activities and security of the construction site.

The agreed plan shall be adhered to throughout the construction of the development.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and **xxxxxx** of the Local Plan

CEMPF Construction Environmental Management Plan - Footnote

Noisy construction related activities should not take place outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00hours Saturdays
- With no noisy activities on Sundays or Public Holidays

Institute of Air Quality Management document “*Guidance on the assessment of dust from demolition and construction*” Version 1.1 2016 provided detailed information regarding dust control.

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists, or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.

EVC1 Electric Vehicle Charging Points - Condition

Before the electrical system is installed, a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:

- A Standard Electric Vehicle Charging point (of a minimum output of 16A/3.5kW) for each residential unit that has a dedicated parking space

Buildings and parking spaces that are to be provided with charging points shall not be brought into use until the charging points are installed and operational. Charging points installed shall be retained thereafter.

Reason: In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP24 and LP51 of the Kirklees Local Plan and Chapters 2, 9 and 15 of the National Planning Policy Framework.

EVF1 Electric Vehicle Charging Points – Footnote

A Standard electric vehicle charging point is one which is capable of providing a continuous supply of at least 16A (3.5kW). A 32A (7kW) is however more likely to be futureproof

Standard charging points for single residential properties that meet the requirements specified in the latest version of “*Minimum technical specification - Electric Vehicle Homecharge Scheme (EVHS)*” by the Office for Low Emission Vehicles will be acceptable. Basically, charging points that provide Mode 3 charging with a continuous output of least 16A (3.5kW) and have Type 2 sockets would be acceptable.

The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity.

The installation must comply with all applicable electrical requirements in force at the time of installation.