

Consultation Response from KC Environmental Health – Pollution & Noise Control
2020/93272
Howard Street, Batley, Kirklees
Erection of storage unit
Date Responded:
19th November 2020
Responding Officer:
Joanne Cooper
Responding Ref:
WK/202032379

In regards to the application for a new storage unit off Howard Street in Batley there are some areas of Environmental Health concern which the applicant will need to address in regards to land contamination. There are also concerns regarding the noise from vehicles at the proposed unit which may affect nearby noise sensitive residential receptors which requires hours of deliveries and dispatches to be conditioned.

Standard conditions in relation to construction working times and the provision of electric vehicle charging points will also apply to this application.

Land Contamination

Historic land use has indicated that there is a potential for contaminants to be present in the ground which may affect future users of this site. As such full land contamination conditions will need to be applied to assess the risk of contaminants and provide mitigation measures if appropriate.

Noise

Due to the close proximity of nearby noise sensitive residential receptors consideration needs to be made for the noisy impact of vehicles to and from the premises. As such the hours of deliveries and dispatches will need to be conditioned. The applicant has requested that the business operate from 07:00 to 19:00 and has not specified days of operation. Due to the nature and location of the business we recommend that the hours of delivery be conditioned to 07:00 to 19:00 Monday to Saturday. It is recommended that deliveries and dispatches are not made on a Sunday. Should the applicant wish to intensify use of the site in the future it may lead to an increase in noisy activity so the condition is recommended to protect nearby noise sensitive receptors on Sundays.

Should the applicant wish to vary these hours they may do so with a variation of condition application to explain and justify why extended hours would be appropriate.

Due to the nearby noise sensitive receptors construction times shall be conditioned to lessen the impact of noise generated from construction activities.

Air Quality

To bring the development in line with the West Yorkshire Low Emissions Strategy there shall be a provision of electric vehicle charging points as detailed in the condition below.

Conditions

Land Contamination

CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition

Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC3 Submission of Remediation Strategy - Condition

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC4 Implementation of the Remediation Strategy - Condition

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered [in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report] is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC5 Submission of Validation Report - Condition

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for (that part of) the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Validation Report in respect of those remediation measures has been approved in writing by the Local Planning Authority. Where validation has been submitted and

approved in stages for different areas of the whole site, a Final Validation Summary Report shall be submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC 7 Contaminated land - Footnote

All contamination reports shall be prepared in accordance with guidance in:

- *Land Contamination Risk Management (LCRM)*
- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group

Noise

HUC3 Hours of Use for Deliveries – Condition

There shall be no deliveries to or dispatches from the premises outside the hours of 07:00 and 19:00 Monday to Saturday

No deliveries shall take place on Sundays or Bank Holidays.

Reason: To ensure that the proposed use(s) does not give rise to the loss of amenity to nearby residential properties, by reason of noise or disturbance at unsociable hours, to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

CSC1 Construction Site Working Times - Condition

Noisy construction related activities shall not take place outside the hours of:

07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00 hours Saturdays

With no noisy activities on Sundays or Public Holidays

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.

Air Quality

EVC1 Electric Vehicle Charging Points - Condition

Before the electrical system is installed a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:

- One Standard Electric Vehicle Charging Point providing a continuous supply of at least 16A (3.5kW) for at least 10% of non-residential parking spaces

Buildings and parking spaces that are to be provided with charging points shall not be brought into use until the charging points are installed and operational. Charging points

installed shall be retained thereafter.

Reason: In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP24 and LP51 of the Kirklees Local Plan and Chapters 2, 9 and 15 of the National Planning Policy Framework.

EVF1 Electric Vehicle Charging Points – Footnote

- A Standard Electric Vehicle Charging Point is one which is capable of providing a continuous supply of at least 16A (3.5kW) and up to 32A (7kW). The higher output is more likely to be futureproof
- At non-residential developments, the requirement for one standard electric vehicle charging point for at least 10% of parking spaces may initially be reduced to one charging point for at least 5% of parking spaces with the remainder provided at an agreed trigger point.
- For developments where some or all of the parking is likely to be used for shorter stay parking (30mins to 4 hours) then Fast (7-23kW) or Rapid (43kW+) charging points may be more appropriate. If Fast or Rapid charging points are proposed together with restrictions on the times that vehicles are allowed to be parked at these points then a lower number of charging points may be acceptable.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity.
- The installation must comply with all applicable electrical requirements in force at the time of installation.