Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2020/93297 - 8 Dowker Street, Milnsbridge, Huddersfield, HD3 4JB.		
Conversion of one dwelling to two flats (Listed Building within a Conservation Area)		
Date Responded: 11th November 2020	**Responding Officer:** Natalie Heaney	**Responding Ref:** WK/202030481

Noise

The proposed development is adjacent to an electricity substation and near an industrial estate. The application plans to open a window on the façade facing the substation and place bedrooms level with the highway. These raise concern that future occupiers at the development may be negatively impacted by noise from the substation, road traffic and commercial activities relating to the industrial estate nearby whilst inside the property. The applicant must demonstrate that acceptable sound levels can be achieved indoors in amenity areas, therefore, noise conditions are necessary. In addition, to protect the residential amenity of neighbouring properties, conditions restricting the hours of construction are appropriate.

Contaminated Land

As only minor groundworks are required for the proposed conversion, conditions are required should unexpected contamination be encountered.

Recommendations

NC9 Noise Assessment Report and Mitigation Scheme - Condition

Before construction work commences a report specifying the measures to be taken to protect the development from noise from all significant noise sources that are likely to affect the proposed development including road traffic, the electricity substation and commercial premises shall be submitted to and approved in writing by the Local Planning Authority.

The report shall:

a) Determine the existing noise climate

b) Predict the noise climate in bedrooms (night-time) and other habitable rooms of the development

c) Detail the proposed attenuation/design necessary to protect the amenity of the occupants of the new residences (including ventilation if required).

The development shall not be occupied until all works specified in the approved report have been carried out in full and such works shall be thereafter retained.

NF4 Competent Person - Footnote

All noise assessments should be carried out by a competent person. Developers may wish to contact the Association of Noise Consultants http://www.association-of-noise-consultants.co.uk/ (020 8253 4518) or the Institute of Acoustics http://www.ioa.org.uk (0300 999 9675) for a list of members.

CSC1 Construction Site Working Times - Condition

Noisy construction related activities shall not take place outside the hours of:
07.30 to 18.30 hours Mondays to Fridays
08.00 to 13.00 hours, Saturdays
With no noisy activities on Sundays or Public Holidays
Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and xxxxx of the Local Plan

CSF1 Construction Sites working times – Footnote
Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.

CLC6 Reporting of Unexpected Contamination - Condition
In the event that contamination not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Validation Report in respect of those works has been approved in writing by the Local Planning Authority.
Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC 7 Contaminated land - Footnote
All contamination reports shall be prepared in accordance with guidance in:

- *Land Contamination Risk Management (LCRM)*
- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group