



ARP Geotechnical Ltd 5 & 6 Northwest Business Park, Servia Hill, Leeds, LS6 2QH
☎ 0113 245 8498 ✉ leeds@arpgeotechnical.co.uk 🌐 www.arpconsultingengineers.co.uk

Mr G Hussain
Adam Bro Properties Ltd
30 Red Hall Way
Leeds
LS14 1DY

BY E-MAIL

Our Ref: F1/ALT/01/JRnml1

4th April 2021

Dear Mr Hussain

Land Adjacent to 33 Sackville St, Ravensthorpe, Dewsbury
Coal Mining Stability Risk Assessment

In accordance with our commission, we are pleased to provide an assessment of the stability of the site with regard to coal mining. Details are provided below. The site is located on the northwest side of Sackville Street, around 20m southwest of the junction with Red Laithes Lane. The site is currently occupied by a double detached garage, drive, and gardens, to No. 33 Sackville Street. The site lies at an approximate elevation of 43m AOD.

Geology

The 1:10,000 scale Geological Map (Sheet SE22SW – Heckmondwike, Solid and Drift), and the 1:50,000 scale Geological Map (Sheet 77, Huddersfield, Solid and Drift) along with the latest British Geological Survey (BGS) electronic data at 1:50,000 scale (which is public sector information licensed under the Open Government License v3.0), have been used to assess the geology of the local area. An oblique view geological map overlay for the site is attached, with the drift deposits omitted so that the solid strata, coal seam outcrops, and faults can be seen.

The geological map shows the site to be underlain by alluvium deposits comprising clay, silt, sand and gravel. The bedrock geology is shown to comprise Undifferentiated Strata (mudstone, siltstone and minor sandstone) of the Pennine Lower Coal Measures Formation. BGS archive boreholes in the vicinity indicate the superficial deposits to be present to approximately 10m depth.

The Middleton Main Coal Seam is conjectured to subcrop approximately 50m east of the site, at an elevation of 42m AOD, and the Wheatley Lime Coal seam is conjectured to subcrop approximately 120m to the west of the site, at an elevation of approximately 43m AOD. The Generalised Vertical Section (GVS) indicates the Middleton Main Coal Seam is younger than (above) the Wheatley Lime Coal Seam. Therefore, the strata are deepening to the east, so that the Wheatley Lime underlies the site and the Middleton main does not.

The Eleven Yard Coal seam is shown by the GVS to be present approximately 6m below the Wheatley Lime Coal seam. This seam is not shown to subcrop in the general area of the site, probably due to topographical effects and extensive faulting in the wider surrounding area. The Wheatley Lime Coal seam is indicated to be between 0.7m and 0.8m thick in the locality, and the



Middleton Eleven Yard Coal seam is indicated to be between 0.3m and 1.1m thick. The Blocking Rider Coal seam is approximately 19m below the Middleton Eleven Yard Coal and has an indicated thickness of 0m to 0.2m.

The strata are indicated to have a dip of around 3° to the east on dip recordings on the adjacent fault block. Therefore, based on the maps and elevations, the Wheatley Lime Coal seam is likely to underlie the site at an approximate depth of 7m below the base of the alluvium. As a result, the Middleton Eleven Yard Coal seam is likely to be approximately 13m below the base of the alluvium.

Further details on the seams and likely depths are given on the table below.

Seam	Approximate Depth Below the Alluvium	Thickness	Coal Seam Within Influencing Distance of Surface
Wheatley Lime Coal	7m	0.7m to 0.8m	YES
Middleton Eleven Yard Coal	13m (based on GVS)	0.3m to 1.1m	YES
Blocking Rider Coal	32m (based on GVS)	0m to 0.2m	NO

Coal Authority and Coal Mining Report

A CON29M Coal Mining Report by Terraforma was obtained by ARP Geotechnical Ltd, and a copy is attached to this letter.

The report states that the site is situated above recorded deep (>30m depth) underground coal mine workings. The approximate depth of these workings is between 56m and 172m below ground level, and last worked in 1895.

The site is not within a surface area that could be affected by historical, known shallow (<30m depth) underground coal workings. However, the site is suspected to be underlain by unrecorded shallow underground coal mine workings. Coal may have been historically worked at depths of less than 30m below the site.

The site is not situated within an area which could be affected by currently active or future proposed underground coal mining. Reserves of coal exist in the local area which could be worked in the future, although ARP considers future underground workings to be highly unlikely given the effective abandonment of the UK coalfields.

There are no recorded mine entries within 20m of the site.

The site is not situated within any past Licence Area for the opencast extraction of coal. The site is not situated within an unlicensed opencast coal mining area. The site is not affected by any present or future proposed opencast coal mining.



Assessment of Coal Mining Instability – Conclusions

It is a generally accepted rule of thumb that unless there is at least 10 times the seam thickness of rock cover above any underground workings, they have the potential to adversely affect ground stability on the site. It is anticipated, therefore, that the Wheatley Lime Coal seam and the Middleton Eleven Yard Coal seam pose a risk to ground stability on the site. The workings would probably take the form of pillar and stall workings. There is a slight risk of unrecorded mine entries on the site, but there are no recorded mine entries within 20m of the site.

The Blocking Rider Coal seam is sufficiently deep to prevent any adverse ground stability effects on the site.

In the light of the above, it is recommended that a rock drilling investigation is carried out to check for any evidence of workings in both seams. Such borehole investigations are usually carried out following grant of planning permission, but before commencement of development. The planning permission will usually include a condition relating to the investigation and possible future treatment of mine workings. The slight potential for unrecorded mine shafts can be addressed by the attendance of a geotechnical engineer to inspect any suspect features found during development works. Any shafts on site would need to be lined, for example by brick or stone, as they would not be self-supporting through the alluvial deposits on site.

The presence of mine workings is not a significant obstacle to development, and there are economical engineering solutions available. ARP provides advice on, and designs, such treatment solutions on a regular basis.

We trust the above information is sufficient for your purposes, but if you have any queries, please do not hesitate to contact us, at your convenience.

Yours sincerely

J Race

Encs



0m 800m
Approximate Scale



ARP GEOTECHNICAL LTD
CHARTERED CONSULTING ENGINEERS

Northwest House 5-6 Northwest Business Park Savile Hill Leeds LS6 2QH
Telephone : 0113 245 8498 Fax : 0113 244 3864 E-Mail : leeds@arpassociates.co.uk

Project **LAND ADJACENT**
33 SACKVILLE STREET
RAVENSTHORPE

Client
ALTAS REAL ESTATE LTD

Title
SITE LOCATION PLAN

Date
MARCH 2021

Drawn JR	Scale AS SHOWN
--------------------	--------------------------

Job No.
ALT/01



0m 10m

Approximate Scale

ARP

**ARP GEOTECHNICAL LTD
CHARTERED CONSULTING ENGINEERS**

Northwest House 5-6 Northwest Business Park Senvia Hill Leeds LS6 2QH
Telephone: 0113 245 8498 Fax: 0113 244 3864 E-Mail: leeds@arpassociates.co.uk

Project LAND ADJACENT
33 SACKVILLE STREET
RAVENSTHORPE


Client
ALTAS REAL ESTATE LTD

Title
AERIAL PHOTOGRAPH

Date
MARCH 2021

Drawn JR	Scale AS SHOWN
--------------------	--------------------------

Job No. ALT/01



ARP GEOTECHNICAL LTD
CHARTERED CONSULTING ENGINEERS

Northwest House 5-6 Northwest Business Park Senvia Hill Leeds LS6 2QH
Telephone: 0113 245 8498 Fax: 0113 244 3864 E-Mail: leeds@arpassociates.co.uk

Project **LAND ADJACENT TO
33 SACKVILLE STREET
RAVENSTHORPE**

Client
ALTAS REAL ESTATE LIMITED

Title
**GEOLOGY OBLIQUE VIEW
PLAN**

Date
MARCH 2021

Drawn JR	Scale NOT TO SCALE - OBLIQUE VIEW
--------------------	---

Job No.
ALT/01

Overall Result:

PASSED

Expert Opinion:

Within the scope of this assessment, the Site is not considered to be susceptible to coal mining-related ground instability. Any identified coal mining features are considered unlikely to impact the value or security of the Site for normal lending purposes and there is no reason for them to impact upon the completion of this transaction.

Will coal mining activity impact the value of the property?

UNLIKELY TO IMPACT VALUE



Are there adverse mining features that should be brought to the lender's attention?

NO NEED TO NOTIFY LENDER



Are there mining hazards that should be brought to the purchaser's attention?

HAZARDS IDENTIFIED



It is important to be fully informed of all coal mining risks associated with a property before completing your purchase. **Please read the next steps section carefully.**

Within Coal Mining Reporting Area

YES

CON29M Questions	Assessment		
Q1. Past underground coal mining	YES	ADVISORY	
Q2. Present underground coal mining	NO	PASSED	
Q3. Future underground coal mining	NO	PASSED	
Q4. Shafts and adits (mine entries)	NO	PASSED	
Q5. Coal mining geology	NO	PASSED	
Q6. Past opencast coal mining	NO	PASSED	
Q7. Present opencast coal mining	NO	PASSED	
Q8. Future opencast coal mining	NO	PASSED	
Q9. Subsidence Claims (Incl. Subsidence Claims Buffer Report)	NO	PASSED	
Q10. Mine gas emissions	NO	PASSED	
Q11. Emergency Call Out incidents	NO	PASSED	
Q12. Withdrawal of support	NO	PASSED	
Q13. Working facilities orders	NO	PASSED	
Q14. Payments to owners of former copyhold land	NO	PASSED	

Official Coal Authority Licensed Data: V1_218_20210222_F | 26-02-2021

Report Address:

Land Adjacent To 33, Sackville Street, Ravensthorpe, Dewsbury, West Yorkshire, WF133BX

Report Details:

TF Reference:
TFC20210303181518-WF133BX

Client Reference: ALT/01

Date: 03/03/2021

User Key:

Lender Attention

Conveyancer Further Action

Purchaser Advisory

Passed - No Further Action

These colour signatures are used throughout the report. Please see the back of the report for a full key.

Please see below Terrafirma's expert opinion and next steps with regards to the property. These may be copied into your Report on Title. No physical site inspection has been carried out. This official CON29M report highlights only the information which we have determined should be drawn to your attention however, other risks may be present. Relevant prudent enquiries for the purchaser are highlighted within the Next Steps section.

● ● Report Conclusions:

Mining features have been identified within the physical influence of the Site, resulting in a susceptibility to past, present and/or future ground movement. Below exist relevant interpreted conclusions based on the findings of this report (where applicable):

Unrecorded shallow coal mine workings are suspected in this area and where present, movement in any worked coal seams beneath the Site, may cause ground instability at the surface.

Any previous movement in the ground should already be present in pre-existing structural defects; please see the report recommendations for further information.

● ● Next Steps:

Terrafirma consider it prudent that an appropriate commercial RICS Structural and/or Building Survey is acquired for any properties/ structures present on the Site in question to assess, amongst other important considerations, their structural condition. This report will highlight any subsidence-related defects, which may relate to ground instability, while also noting any serious or dangerous issues that may require attention. This survey will also include advice on any defects, repairs or maintenance decisions. Should any future signs of subsidence or collapse be identified, then we recommend you seek further expert assistance, however currently, no further reporting on ground instability is required. Terrafirma can be contacted using the information supplied on the front page of this report.

In the event subsidence has previously occurred or occurs in the future, it is recommended Terrafirma are contacted immediately for advice on practical and appropriate next steps, including how one can make a compensation claim to the Coal Authority. For detailed information on the statutory cover available in coal mining areas, please see the back of this report.

● If you are planning on altering or developing the Site:

The Site is likely located within a 'High Development Risk Zone', as defined by the Coal Authority. Due to the presence of recorded and/or unrecorded coal mining activity, any future development of the Site may trigger ground collapse and/or subsidence.

It should be noted that prior to site works or future development, your local planning authority may require you to commission a full Coal Mining Risk Assessment (CMRA) or Site Investigation by a qualified mining geologist/engineer.

In the event, you require further professional support, please contact Terrafirma directly to discuss the appropriate further steps.


Contact the report author by calling the Terrafirma team on: 0330 900 7500



This official CON29M Non-Residential Coal Mining Report is a site-specific interpretation of coal mining activity. These enquiries are The Law Society CON29M Coal Mining search enquiries and are used with permission of the Law Society. The Law Society CON29M Coal Mining search enquiries are protected by copyright owned by The Law Society of 113 Chancery Lane, London WC2A 1PL. Terrafirma's Terms and Conditions are applicable at the time the report was produced.



Mining Hazard Map



Site Address: Land Adjacent To 33, Sackville Street, Ravensthorpe, Dewsbury, West Yorkshire, WF133BX


Hazard Map Key

Coal Authority Data



Mine Entries



Subsidence Claims



Hazard Zones



Mapping sourced from the Ordnance Survey © Crown copyright [and database rights] OS100058210



The enquiries below are The Law Society CON29M Coal Mining search enquiries and are used with permission of The Law Society. This report is prepared in accordance with The Law Society CON29M (2018) Guidance Notes and ScotForm 2006: Coal mining search in Scotland; under which all replies to these enquiries are made. These fourteen questions and their answers are relevant to a non-residential property and should not be relied upon in a residential transaction.

Detailed findings of coal mining activity:

1. Past underground coal mining

ADVISORY 

Q. *Is the property within the zone of likely physical influence on the surface of past underground coal workings?*

A.

The Site is recorded to be within the surface area of underground coal mine workings of 2 seams of coal. Coal has been mined at an approximate depth of 56 to 172 metres beneath the surface. The last known working date is recorded as 1895.

The Site is not within a surface area that could be affected by historic, known shallow underground coal mining. The Site is suspected to be underlain by shallow coal mine workings. Coal may have been historically worked within at least one seam of coal at depths less than 30 metres beneath the surface. Therefore, shallow unrecorded mine workings may exist beneath or within the vicinity of the Site. Please see the report conclusions for further information.

2. Present underground coal mining

PASSED 

Q. *Is the property within the zone of likely physical influence on the surface of present underground coal workings?*

A.

The Site is not situated within an area which could be affected by currently active underground coal mining.

3. Future underground coal mining

PASSED 

Q. (a) *Is the property within any geographical area for which the Coal Authority is determining whether to grant a licence to remove coal by underground methods?*

(b) *Is the property within any geographical area for which a licence to remove coal by underground methods has been granted?*

(c) *Is the property within the zone of likely physical influence on the surface of planned future underground coal workings?*

(d) *Has any notice of proposals relating to underground coal mining operations been given under section 46 of the Coal Mining Subsidence Act 1991?*

A.

The Site is not situated within an area which could be affected by any future underground coal mining. However, reserves of coal exist in the local area which could be worked at some time in the future.

The Site is not situated within the influence of a Section 46 Notice.



4. Shafts and adits (mine entries)PASSED 

Q. *Are there any shafts and adits or other entries to underground coal mine workings within the property or within 20 metres of the boundary of the property?*

A.

There are no recorded mine entries within 20 metres of the Site.

5. Coal mining geologyPASSED 

Q. *Is there any record of any fault or other line of weakness due to coal mining at the surface within the boundary of the property that has made the property unstable?*

A.

There are no recorded faults, fissures or breaklines that occur within the influence of the Site.

6. Past opencast coal miningPASSED 

Q. *Is the property situated within the geographical boundary of an opencast site from which coal has been removed in the past by opencast methods?*

A.

The Site is not situated within any past licence areas for the opencast extraction of coal.
There are no unlicensed opencast pits or extraction sites beneath the Site.

7. Present opencast coal miningPASSED 

Q. *Is the property within 200 metres of the boundary of an opencast site from which coal is being removed by opencast methods?*

A.

The Site is not situated within an area which could be affected by currently active opencast coal mining.

8. Future opencast coal miningPASSED 

Q. *(a) Is the property within 800 metres of the boundary of an opencast site for which the Coal Authority are determining whether to grant a licence to remove coal by opencast methods?*
(b) Is the property within 800 metres of the boundary of an opencast site for which a licence to remove coal by opencast methods has been granted?

A.



There are no plans by the Coal Authority to grant a licence to extract coal using opencast methods within 800 metres surrounding the Site.

9. Coal mining subsidence claims

PASSED 

Q. (a) Has any damage notice or claim for alleged coal mining subsidence damage to the property been given, made or pursued since 1st January 1994?
(b) Does any current "Stop Notice" delaying the start of remedial works or repairs affect the property?
(c) Has any request been made under section 33 of the 1991 Act to execute preventive works before coal is worked?

A.

There is no record of any coal mining-related damage notices or subsidence claims for the Site or for any Site within 50 metres of the Site.

There is no record of a request that has been made to carry out preventive works before coal is worked under section 33 of the Coal Mining Subsidence Act 1991.

10. Mine gas emissions

PASSED 

Q. Does the Coal Authority have record of any mine gas emission within the boundary of the property being reported that subsequently required action by the Authority to mitigate the effects of the mine gas emission?

A.

There are no records of any Mine Gas hazards within the influence of the Site and there is no record of any Mine Gas emissions requiring action.

11. Emergency surface hazard call out incidents

PASSED 

Q. Have the Coal Authority carried out any work on or within the boundaries of the property following a report of an alleged hazard related to coal mining under the Authority's Emergency Surface Hazard Call Out procedures?

A.

The Site is not situated within the influence of a coal mining-related hazard.

12. Withdrawal of support

PASSED 

Q. (a) Does the land lie within a geographical area in respect of which a notice of entitlement to withdraw support has been published?
(b) Does the land lie within a geographical area in respect of which a revocation notice has been given under section 41 of the Coal Industry Act 1994?

A.

The property is not in an area where notices to withdraw support have been given.



The property is not in an area where a notice has been given under section 41 of the Coal Industry Act 1994, cancelling the entitlement to withdraw support.

13. Working facilities orders

PASSED 

Q. *Is the property within a geographical area subject to an order in respect of the working of coal under the Mines (Working Facilities and Support) Acts 1923 and 1966 or any statutory modification or amendment thereof?*

A.

The property is not in an area for which any orders have been made under the provisions of the Mines (Working Facilities and Support) Acts 1923 and 1966 or any statutory modification or amendment thereof.

14. Payments to owners of former copyhold land

PASSED 

Q. *Has any relevant notice, which may affect the property, been given?*

A.

The property is not in an area where a relevant notice has been published under the Coal Industry Act 1975/Coal Industry Act 1994.



FURTHER INFORMATION

Key and Colour Information

The below key provides further guidance on the colours used throughout this report.

Lender Attention	Terraforma has identified mining hazards within the vicinity of the Site, including features (e.g., mine shafts/ adits) that could affect the future value of the Site. A lender may want to be alerted to this adverse entry, due to requirements of UK Finance (formerly the Council of Mortgage Lenders), before deciding on whether to proceed with the transaction. The conveyancer is advised to follow the terms of the UK Finance Mortgage Lenders' Handbook and any additional instructions from the prospective lender in its consideration and determination of whether to refer any part of this report to the lender.
Conveyancer Further Action	Terraforma has concluded that further expert analysis of the Site is required. Terraforma does not believe that the transaction should continue until further actions have been undertaken to quantify the risk of subsidence or collapse to the Site. Terraforma recommends that the conveyancer liaises with all necessary parties regarding the report's findings.
Purchaser Advisory	The purchaser's attention is drawn to the prudent advice outlined in the report, which Terraforma recommends is read carefully. The report results should not hinder the transaction and Terraforma's Terms & Conditions are valid for the Site.
Passed No Further Action	Terraforma has not identified any mining features that influence the ongoing use or value of the Site. Terraforma does not believe that any further actions are required for this transaction and Terraforma's Terms & Conditions are valid for the Site.

Additional Remarks

These enquiries are The Law Society CON29M (2018) Coal Mining search enquiries and are used with permission of the Law Society. The Law Society CON29M Coal Mining search enquiries are protected by copyright owned by the Law Society of 113 Chancery Lane, London WC2A 1PL. The Law Society has no responsibility for information provided in response to CON29M (2018) Coal Mining search enquiries within this report or otherwise. This report is prepared in accordance with The Law Society Guidance Notes 2018 and ScotForm 2006: coal mining search in Scotland; under which all replies to these enquiries are made. Terraforma's Terms and Conditions are applicable at the time the report was produced.

Future Development

In scenarios where mining activity has been identified, a prudent developer would seek appropriate technical advice before any works are undertaken.

In these areas, if development proposals are being considered, technical advice relating to both the investigation of coal and former coal mines and their treatment should be obtained before beginning work on site. All proposals should apply good engineering practice developed for mining areas. No development should be undertaken that intersects, disturbs or interferes with any coal or mines of coal without the permission of the Coal Authority.

Developers should be aware that the investigation of coal seams/former mines of coal may have the potential to generate and/or displace underground gases and these risks both under and adjacent to the development should be fully considered in developing any proposals. The need for effective measures to prevent gases entering into public properties either during investigation or after development also needs to be assessed and properly addressed. This is necessary due to the public safety implications of any development in these circumstances.



Notice of Statutory Cover

In the unlikely event of any future damage, the terms of the Coal Mining Subsidence Act 1991 (as amended by the Coal Industry Act 1994) may apply*, and the Coal Authority / Licensee has a duty to take remedial action in respect of subsidence caused by the withdrawal of support from land and/or property in connection with lawful coal-mining operations. Typically, these actions will not need to involve either your insurance company or mortgage lender and therefore the end user(s) should not incur any costs or liability. *Note: this Act does not apply where coal was worked or gotten by virtue of the grant of a gale in the Forest of Dean, or any other part of the Hundred of St. Briavels in the county of Gloucester.

In addition to the above, it should also be noted that the Coal Authority offer a Public Safety and Subsidence Department that provides a 24-hour 7 day a week call out service (Tel: 01623 646 333) to take remedial action in respect of hazards associated with the movement or collapse of any coal mineshaft or entrances to coal mines and from other coal mining related surface hazards. Further information can be found on their website: <https://www.groundstability.com/>.

Limitations

This CON29M Coal Mining Report has been carried out with reference to all available official Coal Authority licensed data, an extensive collection of abandoned mine plans, maps, and records. From this material, we have endeavoured to provide as accurate a report as possible. Any and all analysis and interpretation of licensed Coal Authority data in this report is made by Terraforma.

Information provided by Terraforma in this report is compiled in response to The Law Society CON29M Coal Mining search enquiries and ScotForm 2006 coal mining search in Scotland. The scope of the assessment is concerned only with the interpretation of past, present and future extraction of coal minerals. This report does not consider the impact from non-coal mining hazards and/or natural ground stability hazards, such as subsidence, landslip or coastal erosion. For an expert opinion on all mining and ground hazards and in order to meet the requirements of Law Society Guidance Notes (2018) and best practice guidance in the 25th Edition Conveyancing Handbook (2018), you may choose to obtain a Terraforma Ground Report by contacting a member of the team.

This report is a 'remote' investigation and reviews only information provided by the client and from the databases of publicly available information that have been chosen to enable a desk based environmental assessment of the Site. The report does not include a Site Investigation, nor does Terraforma make specific information requests of the regulatory authorities for any relevant information they may hold.

This report is concerned solely with the Site searched and should not be used in connection with adjacent properties as only relevant known mining features have been mentioned and any known features that could potentially have a direct influence upon the target Site. Other features which may be present in the general area may have been omitted for clarity.

The report is based upon the Site boundaries as shown on the supplied location plan. This report is confidential to the client, the client's legal advisor and the client's Mortgage lender, as defined in the Terraforma & TerraSearch® terms & conditions, and as such may be used by them for conveyancing or related purposes. We have no liability toward any person or organisation not party to commissioning this report. This report or any part of it is not permitted to be reproduced, copied, altered or in any other way distributed by any other person or organisation.



Terms and Conditions

Report produced by Terraforma IDC LTD © 2021.

This report is provided under the Terraforma Terms and Conditions, a copy of which is available on our website at: https://www.terrafirmaidc.co.uk/terms_and_conditions. They provide a limit of liability per report of £10 million, backed by Professional Indemnity Insurance; details available on request.

Licensing

This report contains Data provided by the Coal Authority. Any and all analysis and interpretation of Coal Authority Data in this report is made by Terraforma IDC Ltd and is in no way supported, endorsed or authorised by the Coal Authority. The use of the data is restricted to the terms and provisions contained in this report. Data reproduced in this report may be the copyright of the Coal Authority and permission should be sought from Terraforma IDC Ltd prior to any re-use.

© Crown Copyright (2021) Ordnance Survey License Number 0100020315. May contain British Geological Survey materials © NERC (2021).

This report may contain public sector information licensed under the Open Government Licence v3.0.

This report may contain plans and records held by the Coal Authority and made publicly available at the time of inspection which may include British Geological Survey and Ordnance Survey data.

The Law Society CON29M Coal Mining search enquiries are protected by copyright owned by The Law Society of 113 Chancery Lane, London WC2A 1PL.



Important Consumer Information

This search has been produced by **TERRAFIRMA IDC LTD** – Address: 2440 The Quadrant, Aztec West Business Park, Almondsbury, Bristol, BS32 4AQ; Email: info@terrafirmaidc.co.uk; Telephone: 0330 900 7500, which is registered with the Property Codes Compliance Board (PCCB) as a subscriber to the Search Code. The PCCB independently monitors how registered search firms maintain compliance with the Code.

This report meets the principles and requirements of the Property Codes Compliance Board Compliance Note CN02J in respect of Coal Mining Searches.

The Search Code

- provides protection for homebuyers, sellers, estate agents, conveyancers and mortgage lenders who rely on the information included in property search reports undertaken by subscribers on residential and commercial property within the United Kingdom
- sets out minimum standards which firms compiling and selling search reports have to meet
- promotes the best practice and quality standards within the industry for the benefit of consumers and property professionals
- enables consumers and property professionals to have confidence in firms which subscribe to the code, their products and services.

By giving you this information, the search firm is confirming that they keep to the principles of the Code. This provides important protection for you.



The Search Code

The Code's core principles (Firms which subscribe to the Search Code will):

- display the Search Code logo prominently on their search reports
- act with integrity and carry out work with due skill, care and diligence
- at all times maintain adequate and appropriate insurance to protect consumers
- conduct business in an honest, fair and professional manner
- handle complaints speedily and fairly
- ensure that products and services comply with industry registration rules and standards and relevant laws
- monitor their compliance with the Code

CONTACT TERRAFIRMA IF YOU WOULD LIKE A COPY OF THE SEARCH CODE

Complaints

If you have a query or complaint about your search, you should raise it directly with the search firm, and if appropriate ask for any complaint to be considered under their formal internal complaints procedure. If you remain dissatisfied with the firm's final response, after your complaint has been formally considered, or if the firm has exceeded the response timescales, you may refer your complaint for consideration under The Property Ombudsman scheme (TPOs). The Ombudsman can award up to £5,000 to you if the Ombudsman finds that you have suffered actual financial loss and/or aggravation, distress or inconvenience as a result of your search provider failing to keep to the Code.

Please note that all queries or complaints regarding your search should be directed to your search provider in the first instance, not to TPOs or to the PCCB.

TPOs Contact Details:

The Property Ombudsman scheme, Milford House, 43-55 Milford Street, Salisbury, Wiltshire SP1 2BP, Tel: 01722 333306, Fax: 01722 332296, Email: admin@tpos.co.uk, Web site: www.tpos.co.uk.

You can get more information about the PCCB from www.propertycodes.org.uk or from our website at <https://www.terrafirmaidc.co.uk>.

Complaints Procedure

If you want to make a complaint directly to Terrafirma, we will:

- Acknowledge it within 5 working days of receipt.
- Normally deal with it fully and provide a final response, in writing, within 20 working days of receipt.
- Keep you informed by letter, telephone or e-mail, as you prefer, if we need more time.
- Provide a final response, in writing, at the latest within 40 working days of receipt.
- Liaise, at your request, with anyone acting formally on your behalf.

Complaints should be sent to: **Senior Executive, Terrafirma IDC LTD** - Address: 2440 The Quadrant, Aztec West Business Park, Almondsbury, Bristol, BS32 4AQ; Email: info@terrafirmaidc.co.uk; Telephone: 0330 900 7500.

If you are not satisfied with our final response, or if we exceed the response timescales, you may refer the complaint to The Property Ombudsman scheme (TPOs): Tel: 01722 333306, E-mail: admin@tpos.co.uk. We will co-operate fully with the Ombudsman during an investigation and comply with his final decision.

WE TRUST THIS REPORT PROVIDES THE INFORMATION YOU REQUIRE. PLEASE CONTACT US IF YOU HAVE ANY QUERIES OR IF WE CAN BE OF ANY FURTHER ASSISTANCE.



CON29M Coal Report Insurance Backed Guarantee

In the unlikely event that the coal data used by Terra Firma in order to compile their report is later found to be inaccurate, the purchaser of the report benefits from Loss of Value Protection of up to £100,000 and should the purchaser later suffer a financial loss, following their reliance on the report, are protected by Terra Firma.

Terra Firma are protected by an indemnity policy through CLS Property Insight Limited through their insurer Great Lakes Insurance SE, UK Branch. Please note that claims are subject to the terms and conditions of the policy that Terra Firma hold with CLS Property Insight Limited. Terms of this policy can be found below:

Policy Number: GESI 0035553CV

Insurer	Great Lakes Insurance SE, UK Branch Great Lakes Insurance SE is a German insurance company with its headquarters at Königinstrasse 107, 80802 Munich. Great Lakes Insurance SE, UK Branch, is authorised and regulated by Bundesanstalt für Finanzdienstleistungsaufsicht. Deemed authorised by the Prudential Regulation Authority. Subject to regulation by the Financial Conduct Authority and limited regulation by the Prudential Regulation Authority. Details of the Temporary Permissions Regime, which allows EEA-based firms to operate in the UK for a limited period while seeking full authorisation, are available on the Financial Conduct Authority's website.
Insured	Terra Firma IDC LTD
Purchaser	The person who buys the Search Report from the Insured, and/or any of the following: 1. The person who asked for the Search Report in connection with the purchase of the Property (and their mortgagee). 2. The person who purchased the Property (and their mortgagee) if the person selling the Property has asked for a Search Report for the benefit of the Purchaser as part of a seller's pack or if the Property has been purchased by way of auction. 3. The owner of the Property (and their mortgagee) if they are re-mortgaging the Property or the owner of the Property who has chosen to obtain a Search Report. 4. Their estate and beneficiaries, to whom the benefit of the Policy will pass in the event of their death during the Period of Insurance.
Property	Any commercial property for which a Search Report is provided by the Insured for the benefit of the Purchaser during the Period of Insurance.
Search Report	The Terra Firma CON29M Coal Report (or relevant Coal assessment section of any attached Terra Firma report).
Limit of Indemnity	£100,000.00 in the aggregate in respect of any one Property
Effective Date	The date of the Search Report, provided by the Insured to the Purchaser being the date that cover will commence.
Period of Insurance	Cover for each individual Property will be from the Effective Date until the Purchaser of the Search Report either; (a) no longer has an interest in the Property, or, (b) until the date of a Subsequent Search Report is obtained by the Purchaser after the Effective Date, whichever is the sooner.
Insured Use	The continued use of the Property as a commercial property not exceeding 25 hectares as constructed and used at the Effective Date.
Cover	Subject to the terms and conditions of this Policy and provided the Property has been declared to the Insurer and the Premium inclusive of Insurance Premium Tax has been paid to the Administrator, the Insurer will indemnify the Insured during the Period of Insurance in respect of Loss arising from any claim by a Purchaser made against the Insured resulting from inaccurate data having been incorporated into such Search Report.
Market Value	The value of the Purchaser's interest in the title to the Property as determined by a surveyor appointed by agreement between the Insurer and the Insured, but subject to General Condition 11.
Loss	1. The loss in Market Value of the Property directly attributable to any changes in the information revealed in a subsequent Search Report obtained by the Purchaser, which was not revealed in the Search Report provided to the Purchaser, which was carried out on the Effective Date, such loss in Market Value to be calculated at the date of the subsequent Search Report, and 2. All other costs and expenses which have been agreed in advance by the Insurer.
Exclusions	The Insurer will not be liable to indemnify the Insured for: 1. Loss which is or would otherwise be recoverable under a building's insurance policy. 2. Loss arising wholly or partly because of the wilful act or neglect of the Insured. 3. Loss if at the date of a claim the Purchaser is not the legal or beneficial owner of the Property. 4. Loss in relation to loss of a transaction for the sale or for the purchase of the Property and any costs incurred by the Purchaser in relation to the loss of such transaction.



	- Loss in respect of structural or other physical damage caused to the Property by subsidence or flooding after the Effective Date. - Loss as a result of any change in information in response to sections 3 – Future underground coal mining and 8 – Future opencast coal mining of the Search Report carried out at the Effective Date. - Loss in respect of the information in any subsequent Search Report after the Effective Date if this information also appears on the Search Report issued to the Purchaser on that date. - Loss in relation to any change to the CON29M (2018) Search form and/or the Search Report made after the Effective Date which affects the Insurer's responsibility under this Policy, if Insurers would not have been responsible for the Loss before such change. - Loss in relation to the contents of any brine data whatsoever contained within the standalone Terra Firma CON29M Coal Report. - Loss in relation to any change in the interpretation of information upon which Search Report was produced provided such information remains unchanged. - Loss arising from claims made under this Policy by any party other than the Insured.
Claims Conditions	- It is a condition precedent of the Insurer's liability under this Policy that the Policyholder and/or the Purchaser will give written notice to the Administrator at the address shown under "Making a Claim", below, as soon as reasonably practicable, of any circumstances likely to give rise to a claim for which the Insurer may be liable under this Policy and provide the Administrator with such information and documentation as may reasonably be requested. - The Insurer will be entitled to decide how to defend or settle a claim. - The Insurer will be entitled to participate fully in any defence, negotiation or settlement of a claim or circumstance and in any such event the Policyholder and/or the Purchaser will (to the extent reasonably practicable in the circumstances, but without limitation): - not incur any cost or expense without first consulting with and receiving written consent from the Insurer. - not make any admission of liability, offer, settlement, promise, payment or discharge without first consulting with and receiving written consent from the Insurer. - give the Insurer access to and provide the Insurer with copies of all correspondence and documentation available to the Insured in relation to the claim or circumstance and afford the Insurer sufficient time in which to review and comment on such documentation. - inform the Insurer of any proposed meeting with any third party in relation to a claim or circumstance and allow the Insurer to attend such meeting and, if the Insurer so requests, provide a detailed written account of the subject and outcome of any such meeting or discussion at which the Insurer was not present. - conduct all negotiations and proceedings in respect of any claim or circumstance with advisers of which the Insurer has approved in writing and take such action as the Insurer may reasonably require to contest, avoid, resist, compromise or otherwise defend any claim or circumstance. - provide the Insurer with such other information and assistance in connection with any claim or circumstance as the Insurer may reasonably request. - The Insurer will be entitled to all rights and defences it may have in respect of a claim by a Purchaser against any successor to that Purchaser. - If at the time of any claim made under this Policy, there is any other insurance in place whether effected by the Purchaser or by any other person under which the Purchaser may be entitled to make a claim the Insurer will be liable to pay or contribute in respect of a claim under this Policy only rateably with such other insurance. - If the Purchaser makes any claim knowing it to be false or fraudulent as regards amount or otherwise, this Policy will become voidable and all claims under it may be forfeited. - In the event of any claim under this Policy from a Purchaser where the Policyholder has failed to make the required declaration and/or has failed to pay the Premium due to the Insurer via the Administrator but the Insurer is still required to deal with the claim from the Purchaser, the Insurer will be entitled to seek recovery from the Policyholder of all claims monies paid to the Purchaser together with the amount of the Insurer's costs incurred in the handling of the claim.
Additional Information	This is a summary of the policy and does not contain its full terms and conditions. A copy of the general conditions is available on request. In the event of a claim, please contact Terra Firma IDC LTD (the 'Insured') in the first instance. Terra Firma's terms and conditions (https://www.terrafirmidc.co.uk/terms_and_conditions) provide an assurance (section 3.8) that in the event of any successful claim, the award will be paid, in full, to the Customer/Purchaser.
Administrator	CLS Property Insight Limited, 17 Kings Hill Avenue, West Malling, Kent, ME19 4UA. CLS Property Insight Limited can be contacted by email at info@clspropertyinsight.co.uk or by telephone on 01732 753 910.   R P Partington Director  Signed by CLS Property Insight Limited on behalf and with the authority of the Insurer

