

Consultation Response from Strategic Waste		
1 Plover Drive, Healey, Batley WF17 8BA		
Erection of single storey rear extension and porch		
Date Response 23.03.21	Responding Officer WT	REF 2021/90842
<p>There is one closed landfill within 250m of application address.</p> <p>Kc Ref 10 (Jail Rd) lies approximately 50m away, 20,000m3 of solid, inert construction and excavation was tipped here.</p> <p>Shallow spike surveys for landfill gas in 1993 produced values of-</p> <p>CH4 <0.1% v/v</p> <p>Co2 0.2% v/v</p> <p>Wayne Thornton Monitoring Officer REF WT3364</p>		