

Consultation Response from KC Environmental Health – Pollution & Noise Control
2021/90940
12 Thornhill Park Avenue, Thornhill, Dewsbury, WF12 0DA
Demolition of existing dwelling and erection of one new dwelling
Date Responded:
11 May 2021
Responding Officer: Kevin
Ellam
Responding Ref:
WK/202114397

I have reviewed the information submitted by the applicant and recommend the following planning conditions:

AIR QUALITY

In an application of this nature, it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary.

EVC1 *Electric Vehicle Charging Points - Condition*

Before the electrical system is installed a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:-

- A Standard Electric Vehicle Charging point (of a minimum output of 16A/3.5kW) for each residential unit that has a dedicated parking space

Buildings and parking spaces that are to be provided with charging points shall not be brought into use until the charging points are installed and operational. Charging points installed shall be retained thereafter.

EVF1 *Electric Vehicle Charging Points – Footnote*

- A Standard electric vehicle charging point is one which is capable of providing a continuous supply of at least 16A (3.5kW). A 32A (7kW) is however more likely to be futureproof
- Standard charging points for single residential properties that meet the requirements specified in the latest version of “*Minimum technical specification - Electric Vehicle Homecharge Scheme (EVHS)*” by the Office for Low Emission Vehicles will be acceptable. Basically, charging points that provide Mode 3 charging with a continuous output of least 16A (3.5kW) and have Type 2 sockets would be acceptable.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity.
- The installation must comply with all applicable electrical requirements in force at the time of installation.

CONTAMINATED LAND

This site has been identified on our mapping system as potentially contaminated land due to its proximity to a landfill site. Contaminated land conditions are therefore necessary.

CLC6 Reporting of Unexpected Contamination - Condition

In the event that contamination not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. Unless otherwise approved in writing by the Local Planning Authority, no part of the site shall be brought into use until such time as the site has been remediated in accordance with the approved Remediation Strategy and a Validation Report in respect of those works has been approved in writing by the Local Planning Authority.

CLC 7 Contaminated land - Footnote

All contamination reports shall be prepared in accordance with *Model Procedures for the Management of Land Contamination – Contaminated Land report 11* (CLR11), National Planning Policy Framework (NPPF) and the Council's Advice for Development documents or any subsequent revisions of those documents.

CONSTRUCTION**CSC1 Construction Site Working Times - Condition**

Noisy construction related activities shall not take place outside the hours of:

07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00hours, Saturdays

With no noisy activities on Sundays or Public Holidays

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.