

**Consultation Response from KC,
Trees****2021/91506 Shop Lane, Kirkheaton, Huddersfield, HD5 0DB****Reserved matters application pursuant to outline permission 2014/92535 for erection of 48 dwellings, formation of access and associated infrastructure****Date Responded:09/06/21****Responding Officer:JR****Responding Ref:85/91**

Based on the information that has been provided, there is no objection to the principle of development. Although, we do need to see an arboricultural method statement, in accordance with BS 5837, to show how the construction phase will be implemented without damage to the adjacent protected trees. This should be provided predetermination,

We also need to see more details about the proposed landscaping scheme to include but not limited to, species, size of planting material, tree pit types to be used, after care maintenance etc. Again, this should be predetermination.