

**Consultation Response from Strategic Waste**

**90 Manor Park Rd, Marsh, Cleckheaton BD19 5BN**

**Erection of single storey rear and 2 storey side extensions**

Date Response 24.05.21

Responding Officer WT

REF 2021/91898

**There is one closed landfill within 250m of application address for which we have details for.**

**Kc Ref 51 (Rawfolds) lies approximately 203m away, there is no indication of a waste disposal licence being issued for this site therefore no information on waste type, depth or quantity are available.**

**Shallow spike surveys for landfill gas in 1993 produced values of-**

**CH4 <0.1% v/v**

**Co2 1.0 v/v**

**Wayne Thornton**

**Monitoring Officer**

**REF WT3398**