

From: [Martin Stephenson](#)
To: [RichardA Gilbert](#)
Subject: RE: 2021/91914 Land to rear of 28 Northorpe Lane, Mirfield - Drainage Volumes
Date: 13 October 2022 12:04:19
Attachments:

I've spoken to Kevin at Newett Homes this morning and he confirms they've changed the hydrobrake to discharge the allowable rate of 4.5 l/s under a 3.0m head (instead of 1.5m previously) this therefore now provides a small increase to the previous storage volume obtained with the longer box culvert.

The revised calculations are therefore acceptable to the LLFA

Regards

Martin Stephenson
Principal Flood Risk Officer
Flood Risk and Drainage Management
Civic Centre 3
Huddersfield
High Steet
HD1 2NF

T: 01484 22 1000 (Ext. 75870)

E: martin.stephenson@kirklees.gov.uk
