

Consultation Response from KC Environmental Health – Pollution & Noise Control
2021/92041
Bank Street, Mirfield, Kirklees
Erection of two dwellings
Date Responded:
11 June 2021
Responding Officer: Kevin
Ellam
Responding Ref:
WK/202118541

I have reviewed the information submitted by the applicant and recommend the following planning conditions:

AIR QUALITY

In an application of this nature, it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary.

EVC1 *Electric Vehicle Charging Points - Condition*

Before the electrical system is installed a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:-

- A Standard Electric Vehicle Charging point (of a minimum output of 16A/3.5kW) for each residential unit that has a dedicated parking space

Buildings and parking spaces that are to be provided with charging points shall not be brought into use until the charging points are installed and operational. Charging points installed shall be retained thereafter.

EVF1 *Electric Vehicle Charging Points – Footnote*

- A Standard electric vehicle charging point is one which is capable of providing a continuous supply of at least 16A (3.5kW). A 32A (7kW) is however more likely to be futureproof
- Standard charging points for single residential properties that meet the requirements specified in the latest version of “*Minimum technical specification - Electric Vehicle Homecharge Scheme (EVHS)*” by the Office for Low Emission Vehicles will be acceptable. Basically, charging points that provide Mode 3 charging with a continuous output of least 16A (3.5kW) and have Type 2 sockets would be acceptable.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity.
- The installation must comply with all applicable electrical requirements in force at the time of installation.

CONTAMINATED LAND

This service has previously reviewed the Phase I Contaminated Land Report by Earth Environmental & Geo Technical dated December 2019 (Ref: Report B1142/19) and agreed with its conclusions. We agreed that a Phase II Contaminated Land Report was required

but that this would be targeted solely at gas monitoring for the site. Therefore I recommend the following conditions:

CLC2 *Submission of a Phase 2 Intrusive Site Investigation Report - Condition*

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1). Groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report has been submitted to and approved in writing by the Local Planning Authority.

CLC3 *Submission of Remediation Strategy - Condition*

[Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further] Groundworks shall not commence until a Remediation Strategy has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

CLC4 *Implementation of the Remediation Strategy - Condition*

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered [in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report] is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

CLC5 *Submission of Validation Report - Condition*

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for (that part of) the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Validation Report in respect of those remediation measures has been approved in writing by the Local Planning Authority. Where validation has been submitted and approved in stages for different areas of the whole site, a Final Validation Summary Report shall be submitted to and approved in writing by the Local Planning Authority.

CLC 7 *Contaminated land - Footnote*

All contamination reports shall be prepared in accordance with *Model Procedures for the Management of Land Contamination – Contaminated Land report 11* (CLR11), National Planning Policy Framework (NPPF) and the Council's Advice for Development documents or any subsequent revisions of those documents.

CONSTRUCTION

CSC1 *Construction Site Working Times - Condition*

Noisy construction related activities shall not take place outside the hours of:

07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00hours, Saturdays

With no noisy activities on Sundays or Public Holidays

CSF1 *Construction Sites working times – Footnote*

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.