

KEY

EV ELECTRIC VEHICLE CHARGING POINT POSITION

MODE 2 CHARGING POINT:
All dwellings to be constructed are to be provided with an IP65 rated domestic 32amp socket, directly wired to the consumer unit with 32 amp cable to an appropriate. This socket should be located where it can later be changed to a 32amp Electric Vehicle Charging Point (EVCP) and can be accessed from the dedicated garage or parking space. Equipment installation should be in accordance with the 'IET Code of Practice for Electric Vehicle Charging Equipment'.



- D UPDATED IN ACCORDANCE AP 02.03.22 WITH THE SITE PLAN FOLLOWING COMMENTS FROM HIGHWAYS OFFICER
- C UPDATED IN ACCORDANCE AP 10.01.21 WITH THE SITE PLAN FOLLOWING COMMENTS FROM PLANNING OFFICER
- B UPDATED IN ACCORDANCE AP 25.11.21 WITH THE SITE PLAN FOLLOWING COMMENTS FROM PLANNING OFFICER
- A UPDATED IN ACCORDANCE AP 09.6.21 WITH THE SITE PLAN

Rev Description Drawn Date

miller homes
Miller Homes Ltd - Yorkshire
Lapwing House
Peel Avenue, Calder Park
Wakefield
West Yorkshire, WF2 7UA
Telephone 0870 336 4600
Fax 0870 336 4602
www.millerhomes.co.uk

Project Title
**WOODHEAD ROAD
HONLEY**

Drawing Title
**ELECTRIC VEHICLE CHARGING
POINT PLAN**

Scale: 1:500
Drawn By: AGISTEN
Checked By: AGISTEN
Authorised By: AGISTEN
Date: May 2022
Job No.: 05
Drawing No.: 05
Revision: D