

Consultation Response from KC Environmental Health – Pollution & Noise Control		
2021/92983		
24 Gynn Lane, Honley, Holmfirth, HD9 6LF		
Erection of single storey rear extension and external alterations		
Date Responded: 4 August 2021	Responding Officer: Kevin Ellam	Responding Ref: WK/202125302
I have reviewed the information submitted by the applicant and recommend the following planning conditions: CONTAMINATED LAND This site has been identified on our mapping system as potentially contaminated land due to its previous use as a Mill (Site 136/15) Contaminated land conditions are therefore necessary. CLC6 <i>Reporting of Unexpected Contamination - Condition</i> In the event that contamination not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy. Following completion of any measures identified in the approved Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. Unless otherwise approved in writing by the Local Planning Authority, No part of the site shall be brought into use until such time as the site has been remediated in accordance with the approved Remediation Strategy and a Validation Report in respect of those works has been approved in writing by the Local Planning Authority. CLC 7 <i>Contaminated land - Footnote</i> All contamination reports shall be prepared in accordance with <i>Model Procedures for the Management of Land Contamination – Contaminated Land report 11</i> (CLR11), National Planning Policy Framework (NPPF) and the Council's Advice for Development documents or any subsequent revisions of those documents. CONSTRUCTION CSC1 <i>Construction Site Working Times - Condition</i> Noisy construction related activities shall not take place outside the hours of: 07.30 to 18.30 hours Mondays to Fridays 08.00 to 13.00hours, Saturdays With no noisy activities on Sundays or Public Holidays CSF1 <i>Construction Sites working times – Footnote</i>		

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.