

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2021/93305 - 61-65 New Street, Huddersfield, HD1 2BQ

Change of use and conversion of existing buildings, forming split-level six storey development comprising four-storey stairwell, four-storey roof-top tower block and enclosed courtyard to create 25 dwellings and sub-division of the retail unit forming 61-63 New Street (Full Application)

Responding Date:
12 July 2023

Responding Officer:
Mohammed Nasim

Responding Ref:
WK202318598

Comments

This consultation response is in relation to an amendment in the plans which do not affect our previously submitted comments. Our recommended conditions remain and are repeated below.

Recommended Conditions

NC1 Implement Agreed Noise Mitigation Measures – Condition

Before the development is first brought into use, all works which form part of the sound attenuation scheme as specified in the Environmental Noise Survey, Noise Break-in Assessment & Sound Insulation Scheme authored by NOVA Acoustics dated 13 April 2023 Ref 7856SA v002 –

- a) shall be completed; and
- b) written evidence to demonstrate that the specified noise levels have been achieved shall be submitted to and approved in writing by the Local Planning Authority.

If it cannot be demonstrated that the noise levels specified in the aforementioned Noise Report have been achieved, then a further scheme shall be submitted for the written approval of the Local Planning Authority incorporating further measures to achieve those noise levels. All works comprised within those further measures shall be completed and written evidence to demonstrate that the aforementioned noise levels have been achieved shall be submitted to and approved in writing by the Local Planning Authority before the development is first brought into use.

Reason: To protect the amenity of occupiers of the proposed development from noise or disturbance from nearby noise generating premises to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

NC5B – For use where proposed commercial and residential share a party structure (floor/ceiling or wall etc) – Condition

Before the development is brought into use, the developer shall provide written evidence to the Local Planning Authority to demonstrate that the airborne sound insulation performance of the party floors, walls and ceilings of the development is of a minimum of 55dB $D_{nT,w} + C_{tr}$. If it cannot be demonstrated that the aforementioned airborne sound insulation performance has been achieved, a scheme incorporating further measures to achieve the sound insulation performance shall be submitted for the written approval of the Local Planning Authority. All works comprised within those further measures shall be completed and written evidence to

demonstrate that the aforementioned sound insulation performance level has been achieved shall be submitted to and approved in writing by the Local Planning Authority before the development is first brought into use.

Reason: To protect the amenity of occupiers of the proposed development from noise or disturbance from nearby noise generating premises to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework

CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition

Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework.

CLC2 Submission of a Phase 2 Intrusive Site Investigation Report – Condition

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC3 Submission of Remediation Strategy - Condition

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC4 Implementation of the Remediation Strategy - Condition

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC5 Submission of Validation Report - Condition

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Validation Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Validation Report in respect of those remediation measures has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC 7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2019. Reports must be prepared in accordance with the following guidance -

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group

HUC4 Hours of Use combined Open for Customers, Deliveries and Dispatches – Condition

The use hereby permitted shall not be open to customers outside the hours of -

- 09:00 to 18:00 daily

and there shall be no deliveries to, or dispatches from the premises outside these hours. No deliveries shall take place on Sundays or Bank Holidays.

Reason: To ensure that the proposed use(s) does not give rise to the loss of amenity to nearby residential properties, by reason of noise or disturbance at unsociable hours, to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

CEMPC Construction Environmental Management Plan - Condition

Prior to development commencing, a Construction Environmental Management Plan (CEMP) shall be submitted to and agreed in writing with the Local Planning Authority. The plan shall describe in detail the actions that will be taken to minimise adverse impacts on occupiers of nearby properties by effectively controlling:

- Noise & vibration arising from all construction related activities. This should also

include suitable restrictions on the hours of working on the site including times of deliveries.

- Dust arising from all construction related activities, which should include measures to monitor and record the emissions of dust during construction
- Artificial lighting used in connection with all construction related activities and security of the construction site.

A communications plan detailing the responsible person, their contact details and how this will be communicated to local residents and the Local Authority must be included.

The agreed plan shall be adhered to throughout the construction of the development.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan.

CEMPF Construction Environmental Management Plan - Footnote

No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours, Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Public Holidays.

Institute of Air Quality Management document "*Guidance on the assessment of dust from demolition and construction*" Version 1.1 2014 provides detailed information regarding dust control.

OC1 Kitchen Extract Scheme - Condition

Before food cooking commences, details of a kitchen extract system shall be submitted to and approved in writing by the Local Planning Authority. The details shall provide the following information:

- A risk assessment for odour which considers amount and type of food that will be cooked together with the proposed dispersion of odours and proximity of receptors likely to be affected by any cooking odours.
- Based on the risk assessment, details of the proposed methods of odour control and dispersion of any extracted odours.
- Details showing the proposed location of all the major components of the extract system.
- The noise mitigation measures that will be incorporated in the extract system and details of the likely resulting noise levels that will be caused by operation of the extract system, in particular how loud it will be at nearby noise sensitive locations.
- The proposed ongoing maintenance schedule that will be carried out to ensure that the extract system continues to effectively control odours and not cause excessive noise.

Before food cooking commences the approved extract system shall be installed and thereafter retained and maintained in accordance with the approved details.

Reason: To ensure the proposed development does not cause harmful odour pollution within either a public area or at neighbouring premises in the interest of amenity, to comply with the aims and objectives of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12

and 15 of the National Planning Policy Framework.

Footnote

Detailed advice is available in “*Control of Odour and Noise from Commercial Kitchen Exhaust Systems*” by EMAQ May 2022 which is an update of “Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems” by DEFRA 2005.

DR08 Pollution Prevention (for food outlets including take-aways/restaurants)

Development shall not commence until a scheme to prevent fats, oils, and grease entering the drainage network serving commercial food preparation and dish-washing areas has been submitted to and approved in writing by the Local Planning Authority. The scheme shall be implemented prior to first operation of the development and shall be retained throughout the lifetime of the development.

Reason: To ensure the provision of adequate and sustainable systems of drainage are employed, in the interests of amenity, environmental well-being and to accord with Policy BE1(iv) and the NPPF.

FS1 Food Safety- Footnote

It is recommended that prior to development commencing, the applicant should contact the Food Safety Team of Environmental Services to arrange an advice visit to discuss food safety and hygiene requirements including an appropriate layout. The Food Safety team can be contacted on 01484 22100 (ask for food safety) or by email at food.safety@kirklees.gov.uk.