

Subject: RE: Attached letter from Kirklees Council regarding application number 2021/94208 at location Former North Bierley Waste Water Treatment Works, Cliff Hollins Lane, Oakenshaw, BD12 7ET
Date: 26 November 2021 17:39:31

If the access road to the redevelopment is to be adopted then please arrange for the following condition:

1. Before the development commences a scheme detailing the location and cross sectional information together with the proposed design and construction details for all new retaining walls/ building retaining walls adjacent to the proposed adoptable highways shall be submitted to and approved by the Highway Authority in writing. The approved scheme shall be implemented prior to the commencement of the proposed development and thereafter retained during the life of the development.

Regards

Farhad Khatibi

Bridges & Structures Manager

Structures Section

Highways and Streetscene

Kirklees Council

Highways Service | Flint Street | Fartown | Huddersfield | HD1 6LG

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk

