

<b>Consultation Response from Strategic Waste</b>		
<b>Land @ Lady Ann Rd, Soothill, Batley WF17 0PY</b>		
<b>Erection of 67 dwellings</b>		
Date Response 06.12.21	Responding Officer WT	REF 2021/94280
<p><b>There are two closed landfills within 250m of application address.</b></p> <p><b>KC Ref 111 lies approximately 136m away, shallow spike surveys for LFG in 1993 produced values of-</b>  <b>CH4 0.5% LEL</b>  <b>CO2 Ambient.</b></p> <p><b>KC Ref 169 lies approximately 208m away shallow spike surveys for LFG in 1993 produced values of-</b>  <b>CH4 0.1% v/v</b>  <b>CO2 2% v/v</b></p> <p><b>Wayne Thornton</b>  <b>Monitoring Officer</b>  <b>REF WT3493</b></p>		