

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2022/90272 Greenhead College, Greenhead Road, Huddersfield, HD1 4ES		
Discharge of conditions 11 (CEMP) and 12 (temporary surface water drainage) of previous permission 2021/93674 for partial redevelopment of Greenhead College including demolition and making good, erection of 2 and 4 storey buildings, reconfiguration of parking and access arrangements, reconfiguration of sports provision and other associated external works (within a Conservation Area)		
Responding Date: 23rd February 2022	Responding Officer: Shirley Reynolds	Responding Ref: WK/202203427
<u>Comments</u> We have reviewed Application 2022/90272 in relation to Discharge of Condition 11 (CEMP) only. Condition 11(CEMP) Construction Environment Management Plan Application 2021/93674 required the Applicant to provide additional information with regard to the control and hours of use of construction related lighting. The Revised Construction Management Plan by GallifordTry dated 24/01/22 Rev No. r03, clarifies that all construction lighting will be controlled by photocell activation and only be operational during working hours. Security lighting will be time restricted to 30 seconds. We accept The Construction Management Plan by GallifordTry dated 24/01/22 Rev No. r03. The development shall be carried out strictly in accordance with the approved CEMP and no change there from shall take place without the prior written consent of the Local Planning Authority. Recommendation We recommend that The Construction Management Plan by GallifordTry dated 24/01/22 Rev No. r03. is approved. However, Condition 11 requires the Scheme to be implemented and maintained throughout the construction phase of the development therefore condition 11 should not be fully discharged until the construction at the site has been completed.		