Consultation Response from KC,
Lead Local Flood Authority

2022/90397 Newsome Bowling Green, St John's Avenue, Newsome, Huddersfield, HD4 6JP

Erection of 10 dwellings and associated works

Date Responded: 16th May 2023
Responding Officer: Paul Farndale
Responding Ref:

Further to our comments of 30th May 2022, Kirklees Flood Management & Drainage acting as LLFA OBJECTS to this application on the grounds of an inadequate drainage strategy promoted with a layout.

Permeable paving has been promoted for highways with cellular storage for soakaways positioned in rear gardens. No provisional testing has been done to promote and adequately size this solution.

A pumped surface water solution has been mentioned as an alternative which the LLFA would object to in an area surround by property as this introduces a flood risk not currently present.