

**Consultation Response from KC,
Lead Local Flood Authority**

2022/90752 Land at Hart Street, Newsome, Huddersfield, HD4 6LS

Discharge of condition 3 (surface water drainage in highway) of previous Reserved Matters consent 2021/91638 pursuant to outline permission 2016/91479 (appeal APP/Z4718/W/17/3173711) for erection of 22 dwellings

Date Responded: 1st April 2022

Responding Officer: Paul Farndale

Responding Ref:

Kirklees Flood Management continues to OBJECT to this application as submitted drawings show a flood route from attenuation exceedance entering property curtilage. It is strongly advised and rejected previously, that housing estates should not use cellular storage for attenuation as this does not allow the adequate inspection and maintenance and management required in comparison to other designs, for the LLFA to fulfil its obligations to ensure adequate maintenance and management for the life of the site.