

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2022/91966 Land adj, Sunny Mede, Woodhead Road, Holmfirth, HD9 2PX		
Outline application for erection of residential development		
Responding Date: 24th June 2022	Responding Officer: Shirley Reynolds	Responding Ref: WK202220177
<u>Comments</u> We have reviewed application 2022/91966 and make the following comments and recommendations. Contaminated Land Whilst we have no significant concerns the proposed development involves ground works therefore it will be necessary to recommend a condition relating to unexpected ground contamination. Electric Vehicle Charging Points (EVCP'S) In an application of this nature it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and <i>Air Quality & Emissions Technical Planning Guidance</i> from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary. Construction Noise Construction noise can give rise to loss of amenity to neighbouring noise sensitive receptors, for this reason a condition is necessary to limit the hours of operation for the site. <u>Recommended Conditions</u> CLC6 Reporting of Unexpected Contamination - Condition In the event that contamination, or the presence of coal not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy. Following completion of any measures identified in the approved Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. No part of the site shall		

be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Validation Report in respect of those works has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC 7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2019. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group

EVC1 Electric Vehicle Charging Points - Condition

Before the electrical system is installed a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:

- A Standard Electric Vehicle Charging point providing a continuous supply of at least 16A (3.5kW) for each residential unit that has a dedicated parking space

Buildings and parking spaces that are to be provided with charging points shall not be brought into use until the charging points are installed and operational. Charging points installed shall be retained thereafter.

Reason: In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP20, LP24 and LP47 of the Kirklees Local Plan and Chapters 2, 9 and 15 of the National Planning Policy Framework.

EVF1 Electric Vehicle Charging Points – Footnote

- A Standard Electric Vehicle Charging Point is one which is capable of providing a continuous supply of at least 16A (3.5kW) and up to 32A (7kW). The higher output is more likely to be futureproof
- Standard charging points for single residential properties that meet the requirements specified in the latest version of “*Minimum technical specification - Electric Vehicle Homecharge Scheme (EVHS)*” by the Office for Low Emission Vehicles will be acceptable. Basically, charging points that provide Mode 3 charging with a continuous output of least 16A (3.5kW) and have Type 2 socket outlet would be acceptable.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity.
- The installation must comply with all applicable electrical requirements in force at the time of installation.

CSC1 Construction Site Working Times - Condition

Noisy construction related activities shall not take place outside the hours of:

07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00 hours, Saturdays

With no noisy activities on Sundays or Public Holidays

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and xxxxx of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.