

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**
**2022/92627 179 Lees Hall Road, Thornhill Lees, Dewsbury, WF12 0RW**
**Demolition of existing dwelling and erection of detached dwelling**
**Responding Date:  
6<sup>th</sup> September 2022**
**Responding Officer:  
Shirley Reynolds**
**Responding Ref:  
WK202228389**
**Comments**

We have reviewed application 2022/92627 and make the following comments and recommendations.

**Contaminated land**

The site is not on land identified on our mapping systems as potentially contaminated, it is however in an area with a coal mining legacy and close to land identified as; 1854 coal pits 6inch 1922 brick works/Inghams pit 25inch 1937 reservoir/coal pits/Ingams pit 25inch 1948 pumping station 6inch 1955 Inghams pit 6inch 1966 mine (disused)/mine 6inch 1974 opencast coal working DLS (site ref: 56/11). The risks associated with this legacy should be assessed to protect the amenity of construction staff and future occupiers, we therefore recommend conditions.

**Electric Vehicle Charging Points**

In an application of this nature it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary.

**Construction Noise**

Construction noise can give rise to loss of amenity to neighbouring noise sensitive receptors, for this reason a condition is necessary to limit the hours of operation for the site.

**Recommended Conditions**
**CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition**

Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

**CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition**

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by

a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

### **CLC3 Submission of Remediation Strategy - Condition**

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

### **CLC4 Implementation of the Remediation Strategy - Condition**

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered [in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report] is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

### **CLC5 Submission of Validation Report - Condition**

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Validation Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Validation Report in respect of those remediation measures has been approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

### **CLC 7 Contaminated land - Footnote**

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2019. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*

- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group

### **EVC1 Electric Vehicle Charging Points - Condition**

Before the electrical system is installed a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:

- A Standard Electric Vehicle Charging point providing a continuous supply of at least 16A (3.5kW) for each residential unit that has a dedicated parking space

Buildings and parking spaces that are to be provided with charging points shall not be brought into use until the charging points are installed and operational. Charging points installed shall be retained thereafter.

**Reason:** In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP20, LP24 and LP47 of the Kirklees Local Plan and Chapters 2, 9 and 15 of the National Planning Policy Framework.

### **EVF1 Electric Vehicle Charging Points – Footnote**

- A Standard Electric Vehicle Charging Point is one which is capable of providing a continuous supply of at least 16A (3.5kW) and up to 32A (7kW). The higher output is more likely to be futureproof
- Standard charging points for single residential properties that meet the requirements specified in the latest version of “*Minimum technical specification - Electric Vehicle Homecharge Scheme (EVHS)*” by the Office for Low Emission Vehicles will be acceptable. Basically, charging points that provide Mode 3 charging with a continuous output of least 16A (3.5kW) and have Type 2 socket outlet would be acceptable.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity.
- The installation must comply with all applicable electrical requirements in force at the time of installation.

### **CSC1 Construction Site Working Times - Condition**

Noisy construction related activities shall not take place outside the hours of:

07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00 hours, Saturdays

With no noisy activities on Sundays or Public Holidays

**Reason:** To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and xxxxx of the Local Plan

### **CSF1 Construction Sites working times – Footnote**

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of

the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.