

**Consultation Response from KC,
Lead Local Flood Authority**

2022/93154 Land at, Penistone Road, Fenay Bridge, Huddersfield, HD8 0AW

Erection of 68 dwellings with associated access, parking, open space, landscaping and infrastructure works (including installation of surface water attenuation tank)

Date Responded: 5th June 2023

Responding Officer: Paul Farndale

Responding Ref:

Further to our previous acceptance of this application with appropriate conditions, we would, on light of changes, wish to make sure a highway drain shown discharging to an unknown point in land opposite the site, is fully surveyed and protected from damage from the proposed track and subsequent vehicle loading.