

COPYRIGHT RAMBOLL UK LIMITED. ALL RIGHTS RESERVED. THIS DOCUMENT IS ISSUED FOR THE PARTY WHO COMMISSIONED IT AND FOR THE SPECIFIC PURPOSES CONNECTED WITH THE PROJECT ONLY. IT SHOULD NOT BE RELIED UPON BY ANY OTHER PARTY OR USED FOR ANY OTHER PURPOSE. RAMBOLL ACCEPTS NO RESPONSIBILITY OR LIABILITY WHICH MAY ARISE FROM RELIANCE OR USE OF THIS DOCUMENT OR THE DATA CONTAINED HEREIN BY ANY OTHER PARTY OR FOR ANY OTHER PURPOSE.

- NOTES
- DO NOT SCALE FROM THIS DRAWING.
  - ALL DIMENSIONS ARE IN MILLIMETRES U.N.O.
  - ALL LEVELS ARE IN METRES ABOVE ORDINANCE DATUM U.N.O.
  - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS AND SPECIFICATIONS.

**UNFACTORED VARIABLE LOAD**

PATTERN	DESCRIPTION	LOAD kN/m <sup>2</sup>
	CIRCULATION	4.0
	BEDROOMS	2.0+1.0 (PARTITIONS) = 3.0
	KITCHENS	3.0
	DINING/BANQUET HALL	5.0
	WALKWAYS (2-WAY PEDESTRIAN TRAFFIC)	5.0
	STORAGE SPACE	5.0
	ROOF LOADING (MAINTENANCE ACCESS ONLY)	0.6
	PLANT LOADING	7.5
	GENERAL USE - STAFF CHANGING	2.5
	GENERAL USE - COMMS	3.0
	GYM	5.0
	GENERAL USE	2.5
	WATER TANK LOADING	TBC


**LINE LOADS**

PATTERN	DESCRIPTION	LOAD kN/m
	BALUSTRADE	VERTICAL LOAD = 1.0 VARIABLE HORIZONTAL LOAD (1.2m ABOVE F.F.L.) = 0.74
	ATRIUM ROOF	TBC BY SPECIALIST
	FACADE	ALLOWANCE = 5.0
	PLANT SCREEN	ALLOWANCE = 1.5
	STAIR FOOTING	ALLOWANCE = 15.0

ALL DEAD AND SUPERDEAD LOADS ARE PRELIMINARY AND ARE TO BE CONFIRMED BY THE CONTRACTOR TO SUIT FINAL FINISHES AND ELEVATION DETAILS AND OTHER SECONDARY SYSTEMS.


**UNFACTORED SUPERIMPOSED DEAD LOAD**

PATTERN	DESCRIPTION	LOAD kN/m <sup>2</sup>
	NEW BASEMENT FLOOR	75mm thk SCREED = 1.9 INSULATION & DRAINED CAVITY SYSTEM = 0.5kN/m LOWER SCREED = 1.9
	TYPICAL FLOOR BUILDUP	75mm SCREED = 1.9 ALLOW FOR CEILING & SERVICES = 0.5 TOTAL = 2.4
	TYPICAL WALKWAY	ALLOWANCE = 1.0
	TYPICAL TIMBER FLOOR (BLOCK A)	TIMBER FLOOR BOARDS = 0.21 15MM ACOUSTIC MATTING = 0.120 CEMENT PARTICLE BOARD (28MM) = 0.09 SERVICES = 0.15 INSULATION = 0.02 LATH AND PLASTER = 0.5 TOTAL = 1.09
	TYPICAL ROOF BUILDUP	NEW ROOF SYSTEM = 1.15 BLUE ROOF = 1.0 CEILING AND SERVICES = 0.5 TOTAL = 2.65
	STAIR CORE (OVERRUN) ROOF BUILDUP	ALLOWANCE = 1.0
	EXISTING BASEMENT FLOOR	TBC



PLAN 2  
1 : 100  
LP-STAIRCORE ROOF LEVEL

PLAN 1  
1 : 100  
LP-RF LEVEL



Rev	Description	Date	By	App
P02	PLANNING & LBC ISSUE	16/12/2022	JC	PM
P01	PRELIMINARY DRAFT ISSUE	02/12/2022	JC	PM

S3 - FOR REVIEW AND COMMENT

THE GEORGE HOTEL  
HUDDERSFIELD



LOADING PLAN  
ROOF LEVEL

Project No:	Scale (@ A1):	Date:	Drawn:
1620014217	1 : 100	NOV'22	JC
Drawing No:	Rev:	4217-RAM-ZZ-RF-DR-S-00176	P02