

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2023/90172 114 Fitzwilliam Street, Huddersfield, HD1 5PH

Change of use, alterations, part demolition of boundary wall and erection of two storey side extension to convert from hot food takeaway to residential (Listed Building within a Conservation Area)

**Responding Date:
6th March 2023**

**Responding Officer:
SR**

**Responding Ref:
WK202305866**

Comments

We have reviewed application 2023/90172 and make the following comments and recommendations.

Noise

The site of the proposed development is close to Huddersfield ring road and major roads connecting with the motorway all of which have high traffic volumes, it is also across the road from a large development. Whilst we have no objection to the proposed development the noise impact on the amenity of the future occupiers of these noise sources needs to be considered ensuring appropriate mitigation is applied. A condition requiring a noise assessment report is therefore necessary.

Contaminated land

The site is not on land identified as potentially contaminated. The proposed development involves ground works therefore it will be necessary to recommend a condition relating to unexpected ground contamination.

Electric Vehicle Charging Points

In order to futureproof the proposed development it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary.

Construction Noise

Construction noise can give rise to loss of amenity to neighbouring noise sensitive receptors, for this reason a condition is necessary to limit the hours of operation for the site.

Recommended Conditions

NC9 Noise Assessment Report and Mitigation Scheme - Condition

Before construction work commences a report specifying the measures to be taken to protect the development from noise from all significant noise sources that are likely to affect the proposed development including road traffic and commercial premises shall be submitted to and approved in writing by the Local Planning Authority.

The report shall:

- a) Determine the existing noise climate

- b) Predict the noise climate in living rooms (daytime), bedrooms (night-time) and other habitable rooms of the development
- c) Detail the proposed attenuation/design necessary to protect the amenity of the occupants of the new residences (including ventilation if required).

The development shall not be occupied until all works specified in the approved report have been carried out in full and such works shall be thereafter retained.

Reason: To protect the amenity of occupiers of the proposed development from noise or disturbance from nearby noise generating premises to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

CLC6 Reporting of Unexpected Contamination - Condition

In the event that contamination, or the presence of coal not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Validation Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Validation Report in respect of those works has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 178 and 179 of the National Planning Policy Framework

CLC 7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2019. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group

EVC1 Electric Vehicle Charging Points - Condition

Before the electrical system is installed a scheme detailing the dedicated facilities that will be

provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet the requirements of the current West Yorkshire Low Emission Strategy (WYLES) document. The approved dedicated facilities for charging electric vehicles shall be installed prior to occupation and retained for use thereafter.

Reason: In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP20, LP24 and LP47 of the Kirklees Local Plan, Chapters 2, 9 and 15 of the National Planning Policy Framework and the West Yorkshire Low Emission Strategy (WYLES).

EVF1 Electric Vehicle Charging Points – Footnote

- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.
- The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information in relation to Approved Document S.

CSC1 Construction Site Working Times - Condition

Noisy construction related activities shall not take place outside the hours of:

07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00 hours, Saturdays

With no noisy activities on Sundays or Public Holidays

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.